

From: John Malet-Bates [REDACTED]
Sent: 09 December 2018 21:20
To: Fieldsend, Sofie [REDACTED]
Subject: 2018/4749/P: 14 Prince Arthur Road

Dear Sofie,
HCAAC wishes to have perhaps minor amendments to this proposal, concerning two window openings.

Proposed rear elevation.

The widened rhs opening to the terrace should be retained as existing and any new doors to match those in the adjacent double doors.

Proposed side elevation.

The proposed new opening on the adjacent flank wall should also be narrowed to provide a wider margin for structure at the external wall corner. The need for this new window adjacent to the rear French doors is debatable, but it can certainly stand narrowing.

Regards,
John

John Malet-Bates
For Hampstead CAAC,
[REDACTED]

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer. See our new Privacy Notice [here](#) which tells you how we store and process the data we hold about you and residents.

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer. See our new Privacy Notice [here](#) which tells you how we store and process the data we hold about you and residents.