

**Conservation Area Advisory Committee**

Advisory Committee	Camden Town
Application ref	2018/5996/L
Address	31 Mornington Terrace London NW1 7RS
Planning Officer	Catherine Bond
Comments by	03 Feb 2019
Proposal	Installation of temporary internal secondary glazing to eight windows on the front elevation for noise mitigation during construction of the HS2 railway.
Objection	Yes
Comment	Yes
Observations	We object to such installations without adequate air handling. Ventilation or a cooling system must be required as part of the installation as otherwise the occupants will suffer from overheating and poor air quality on warm days/nights. HS2 should be responsible for ensuring buildings remain habitable if altered to facilitate HS2 works. Eg vents can be sensitively installed in a listed elevation and removed after a period and old fabric replaced.

**Documents attached**

No details entered

**About this form**

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
Form reference	21400570

**Data Protection**

**Data Protection**

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can request that this does not happen.