Our Ref: 172904

Date: 14th January 2018

By e-mail: c/o Simon Baker Simon.Baker@nashbaker.co.uk

Nash Baker 167-169 Kensington High Street London W8 6SH Form

Form Structural Design
77 St John Street

London EC1M 4NN United Kingdom

T: +44 (0) 20 7253 2893 E: studio@form-sd.com

W: www.form-sd.com

Dear Simon,

38 GLENLOCH ROAD ROAD NW3 4DN RESPONSE TO CAMPBELL REITH – BIA AUDIT

Further to the BIA audit dated October 2018 carried out by Campbell Reith I have provided a download link for the various updated reports and their appendices. In summary, the response to the BIA queries are as follows:

Query 1, BIA format: Camden Policy Guidance has been updated in the report to show March 2018 and I can confirm that the CMS checkers qualifications CEng MIstructE

Query 2, BIA Hydrogelogy: Potential for perched groundwater to be considered in BIA- This has been dealt with in the updated report and the CMS has been updated to include a brief methodology on page 9 of the report.

Query 3, BIA land stability: Scoping section, this has been updated in the BIA report.

Query 4, BIA land stability: Typology of neighbouring foundations, this has now been confirmed

and updated in BIA Appendix with updated exploratory hole plan.

Query 5, BIA land stability: Utility search has now been undertaken, see Appendix F in CMS report

Query 6, BIA land stability: Bearing pressure in retaining wall calculation limited to 85kN/M² < 90

Query 7, Stability: Updated GMA provided in Appendix C

Query 8, Stability: Movement monitoring specification provided with suggested trigger

values, refer to Appendix F.

I trust this will now deal with the queries raised by Campbell Reith on the planning application.

Yours sincerely

2/v

Rob Markovits C.Eng M.I.Struct.E

Director

Form Structural Design
Direct Dial: 020 7553 9355
Direct email: robm@form-sd.com