## Building Regulations - Part M4(2) COMPLIANCE KEY

Para. - 2.20 & 21 - PRIVATE ENTRANCES



1200mm x 1200mm UNOBSTRUCTED ENTRANCE PLATFORM, WITH LEVEL ACCESS THRESHOLD, MINIMUM 900mm COVERED ENTRANCE, ILLUMINATED



300mm WIDE UNOBSTRUCTED SPACE TO LEADING EDGE OF ENTRANCE LEVEL DOORS

850mm min 850mm MIN CLEAR OPENING WIDTH TO FRONT DOOR

Para. 2.22 - DOORWAY & HALLWAY WIDTHS

838mm DOORS - MIN CLEAR OPENING WIDTH TO INTERNAL DOORS - GENERALLY 775mm WITH 1050mm

Para. 2.23 - PRIVATE STAIRS 850mm CLEAR WIDTH TO STAIRS for future stair lift (Measured 450mm above pitch) -

Para. 2.24 - HABITABLE ROOMS LIVING ROOM, DINING ROOM & KITCHEN TO BE AT PRINCIPLE LEVEL -




1200mm CLEAR SPACE IN FRONT OF KITCEN UNITS - Para. 2.24 b

LIVING ROOM WINDOW GLAZING TO BEGIN 850MM OR LOWER & WINDOWS EASY TO OPEN - Para. 2.24 c

ACTIVITY ZONE AROUND FURNITURE - Para. 2.25

Para. 2.26 - SANITARY FACILITIES
BATHROOM & WC WALLS TO BE CAPABLE OF TAKING
ADAPTIONS - UP TO 1.5kN/m²

Para. 2.27 & 2.29 - WC & BATHROOMS SANITARY ACCESS - GRND & 1ST FLR -



Para. 2.27 - 1500mm DIAMETER UNOBSTRUCTED TURNING CIRCLE, OVERLAPPINGBATH

Para.227b - SANITARY ACCESS ZONES FOR ONE &TWO BEDROOM ACCOMMODATION

Para. 2.30 - SERVICES CONTROL CONSUMER UNIT MOUNTED BETWEEN 1350 & 1450MM above FFL

SWITCHES, SOCKETS, VENTILATION & SERVICE CONTROLS TO BE BETWEEN 450mm & 1200mm above FFL

ALL HANDLES TO WINDOWS MOUNTED BETWEEN 450 & 1200mm above FFI

BOILER CONTROLS MOUNTED BETWEEN 900 &1200mm above FFL

