

## Muthoora, Leela

---

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 05 February 2019 14:24  
**To:** Planning  
**Subject:** Informative Only Planning Application - 2019/0186/L

London Borough of Camden Our DTS Ref: 100022  
Camden Town Hall Your Ref: 2019/0186/L  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

5 February 2019

Dear Sir/Madam

Re: 2-6, SICILIAN AVENUE, LONDON, WC1A 2QH

### WSTE COMMENT

Thames Water requests that the Applicant should incorporate within their proposal, protection to the property by installing a positive pumped device (or equivalent reflecting technological advances) to avoid the risk of backflow at a later date, on the assumption that the sewerage network may surcharge to ground level during storm conditions. Fitting only a non-return valve could result in flooding to the property should there be prolonged surcharge in the public sewer. If as part of the basement development there is a proposal to discharge ground water to the public network, this would require a Groundwater Risk Management Permit from Thames Water. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing [wwqriskmanagement@thameswater.co.uk](mailto:wwqriskmanagement@thameswater.co.uk). Application forms should be completed on line via [www.thameswater.co.uk/wastewaterquality](http://www.thameswater.co.uk/wastewaterquality)

Thames Water would advise that with regard to waste water network and waste water process infrastructure capacity, we would not have any objection to the above planning application, based on the information provided

### WATER COMMENT

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)