

Conservation Area Advisory Committee

Advisory Committee

Application ref	2018/6023/P
Address	56 Mansfield Road London NW3 2HT
Planning Officer	Samir Benmbarek
Comments by	10 Feb 2019
Proposal	Rebuild and enlargement of existing dormer and installation of 1x replacement rooflight to dwellinghouse
Objection	Yes
Comment	Yes
Observations	The proposed rear dormer seems slightly too large and will be difficult to build as illustrated due to the nearness to the chimney stack. For information the stack seems to be drawn incorrectly in either the plan or the elevation and the dormer roof is not even shown on the proposed drawing. These inconsistencies disguise the problem noted.

Documents attached

No details entered

About this form

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
-----------	--

Form reference	21414138
----------------	----------

Data Protection

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can

Data Protection

request that this does not happen.