



NOTES

1.00 ALL EXTERNAL LIGHTING TO BE CONTROLLED BY PHOTOCELL AND TIME CONTROL.
2.00 ALL EXTERNAL ELECTRICAL FIXTURES SHALL HAVE MINIMUM RATING OF IP65.

SCHEDULE OF SYMBOLS

X2 LUMINAIRE IP65 WALL MOUNTED LED LUMINIAIRE
X3 LUMINAIRE IP65 WALL MOUNTED LED LUMINIAIRE

KEYPLAN






REF 'X3' LUMINAIRE EXTERNAL WALL MOUNTED LED 11W 4000K11 LUMENS CRI80 260DIA 150D



WEST ELEVATION
SCALE 1:100@A1









DRAWING TITLE
ELECTRICAL SERVICES INSTALLATION
SOUTH AND WEST EXTERNAL ELEVATIONS
EXTERNAL LIGHTING LAYOUT
SCALE SIZE PROJECT REE: DRAWING No.

1:100 @ A1 L18051 L18051-IN2-00-XX-DR-E-0101