

Ground Floor

85-87 Hampstead Road

7 & 9 William Road

DREUMOND ROAD

WILLIAM ROAD

HAMPSTEAD ROAD

Entry Fire Exit

Access Way

Remove existing brickwork and fill 6 hour F.R. roller steel shutters in new brick reveals.

Fireable limit to shutter

Open Air

Remove existing roller shutters

Build new brick structure as shown to P.S. 14 for fire resistance also to form airtight door with pair of 1 hr fire resisting doors

Existing 1 hr fire resisting door


New pair of doors in new opening (1 hr fire resisting)

Up

Down to Basement

857

857



LONDON BOROUGH OF CAMDEN
TOWN AND COUNTRY PLANNING ACTS
3 FEB 1982
PLANS ~~NOT APPROVED~~
ON BEHALF OF THE COUNCIL

Drug No. 3507/2^B.