

MCLAREN

Sample Submittal

Project	Luma	Contract No. M1453
Client	Argent	
Package	Façade – Fleetwood	
Submittal Ref	SAM- 49	

Revision	Revision Detail	By	Checked	Date
01	For Comment & Status Assignment			

<p>Subcontractor Name: Fleetwood</p>	<p>Fleetwood House. 480 Bath Road, Slough, Berks. SL1 6BB Tel : 01753 576680</p>
--	--

Submittal Title: DG4 Balustrade Glass Sample

Description	300x300mm sample of our glass spec DG4 made up of; Single Pane: 21.52mm Low Iron Laminated glass with a 1.52 PVB interlayer to take 0.74kN/m barrier loading
Reason for Submittal	<i>State 'as specified' or 'alternate proposal'</i> For approval

Attachments:




McLaren Final Status

Name		Date
Status A	<input type="checkbox"/>	Additional Notes / Comments:
Status B	<input type="checkbox"/>	
Status C	<input type="checkbox"/>	

Sample Submittal Information: (to be completed by Sub-Contractor)

Sub-Contractor:	Fleetwood Architectural Aluminium
Works Package Number:	003
Technical Submittal Title:	DG4 Balustrade Glass Sample
Description:	300x300mm sample of our glass spec DG4 made up of; Single Pane: 21.52mm Low Iron Laminated glass with a 1.52 PVB interlayer to take 0.74kN/m barrier loading
Associated Specification Reference(s):	
Associated Drawing Number(s):	
Manufacturer(s):	Tough Glaze
Material:	Glass
Size:	N/A
Type:	N/A
Model Number:	N/A
Manufacture Process:	N/A
Area/Location for installation:	All facades
Finish/Texture/Pattern/Print:	See above
Colour:	See above
Other/Comments:	

Reviewer Record (to be completed by Reviewers)

Organisation 1: S+P	Name: DEAN STOKER	Comments: Please state status A/B/C SUBJECT TO QUERIES RAISED BY FMDC.
Date: 09.01.19	Signature: 	

Organisation 2:	Name:	Comments: Please state status A/B/C
Date:	Signature:	

Organisation 3:	Name:	Comments: Please state status A/B/C
Date:	Signature:	

TOUGHGLAZE Tel: (0208) 838 4400 Fax: (0208) 838 3311 ** BS EN 12150 C1 / KM52134 **
R73478/001 1 Total: **4** Monday, 26 Nov
 TOUGHGLAZE **SAMPLES**
Fleetwood Architectural Al **HEAT STRENGTHENED**
10mm L Low-Iron Tough **KITE MARK C DIAGRAM**
304 x 304 **Laminate 10mm/10mm**
 2 of 2
 Net Size 300w 300h Fri 23-Nov-18 Fri, 23 Nov, 10:19:41 **F018**
 Web: toughglaze.com email: info@toughglaze.com *R73478001002*

Fleetwood
 Architectural
 Aluminium
 Designed Technical Solutions
 Windows, Doors & Facades

Fleetwood House
 400 Bath Road, Slough
 Berkshire SL1 6BB
 t: 01753 576 600
 f: 01753 505 100
info@faw-group.co.uk
www.faw-group.co.uk

C676 -

BALUSTRADE
GLASS SAMPLE

MCLAREN

Kings Cross Central Project Luma Building R3

Ref: Approval of Reserved Matters Granted 13.11.2015
 Ref 2015/4819/P/Condition 2A
 Discharge of Condition 2A
 SAM: 49 DG4 Balustrade Glass Sample