

Application No:	Consultees Name:	Received:	Comment:	Response:
2019/0556/P	Richard Simpson for Primrose Hill CAAC	24/03/2019 11:54:52	OBJ	<p>ADVICE from Primrose Hill Conservation Area Advisory Committee</p> <p>6 March 2019</p> <p>18 Regent's Park Road NW1 7TX 2019/0556/P</p> <p>We object strongly to the installation of air-conditioning in houses where natural ventilation, including cross-ventilation, is possible.</p> <p>We note that Camden's Local Plan, Policy CC2 'Adapting to climate change', requires all development (and not only those proposing 5 residential units or more) to adopt appropriate climate change adaptation measures, spelling out, in para. 8.39 'The Council will discourage the use of air conditioning and excessive mechanical plant'. At para. 8.42 'Active cooling (air conditioning) will only be permitted where dynamic thermal modelling demonstrates there is a clear need for it after all of the preferred measures are incorporated in line with the cooling hierarchy.'</p> <p>We fully endorse Camden's policy CC2 and ask for it to be upheld.</p> <p>Conservation of our environment in its most basic sense is at risk from climate change: every one of us has a role to play in addressing climate change.</p> <p>Richard Simpson FSA Chair</p>