

From: [REDACTED]  
Sent: 26 March 2019 08:50  
To: Planning [REDACTED]  
Subject: Informative Only Planning Application - 2018/4877/P

London Borough of Camden  
Camden Town Hall  
Argyle Street  
Euston Road  
London  
WC1H 8EQ



26 March 2019


Dear Sir/Madam

Re: 65-67, HOLMES ROAD, LONDON, NW5 3AN

WASTE COMMENT

Thames Water recommends the installation of a properly maintained fat trap on all catering establishments. We further recommend, in line with best practice for the disposal of Fats, Oils and Grease, the collection of waste oil by a contractor, particularly to recycle for the production of bio diesel. Failure to implement these recommendations may result in this and other properties suffering blocked drains, sewage flooding and pollution to local watercourses.

Yours faithfully  
Development Planning Department



This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

