

From: [REDACTED]
Sent: 27 March 2019 15:39
To: Planning [REDACTED]
Subject: Informative Only Planning Application - 2019/1198/L

London Borough of Camden Our DTS Ref: 100263
Camden Town Hall Your Ref: 2019/1198/L
Argyle Street
Euston Road
London
WC1H 8EQ

27 March 2019

Dear Sir/Madam

Re: BASEMENT & GROUND FLOOR, 79-81 HEATH STREET, CAMDEN, LONDON,
NW3 6UG

WASTE COMMENTS:

Thames Water requests that the Applicant should incorporate within their proposal, protection to the property by installing a positive pumped device (or equivalent reflecting technological advances) to avoid the risk of backflow at a later date, on the assumption that the sewerage network may surcharge to ground level during storm conditions. Fitting only a non-return valve could result in flooding to the property should there be prolonged surcharge in the public sewer. If as part of the basement development there is a proposal to discharge ground water to the public network, this would require a Groundwater Risk Management Permit from Thames Water. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing wwriskmanagement@thameswater.co.uk. Application forms should be completed on line via www.thameswater.co.uk/wastewaterquality

With regard to surface water drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website. <https://developers.thameswater.co.uk/Developing-a-large-site/Apply-and-pay-for-services/Wastewater-services>


As you are redeveloping a site, there may be public sewers crossing or close to your development. If you discover a sewer, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes. <https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development/Working-near-or-diverting-our-pipes>.

WATER COMMENTS:

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at [thameswater.co.uk/buildingwater](https://www.thameswater.co.uk/buildingwater).

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully
Development Planning Department



This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

