

Application No:	Consultees Name:	Received:	Comment:	Response:
2019/0452/P	Richard Simpson for Primrose Hill CAAC	04/04/2019 11:27:36	NOBJ	<p>ADVICE from Primrose Hill Conservation Area Advisory Committee 12A Manley Street, London NW1 8LT</p> <p>20 March 2019</p> <p>34 Gloucester Crescent NW1 7DL 2019/0452/P + 2019/0687/L</p> <p>We have no objection of principle to the wholesale repair of the existing slate roof. We note that the intention is to re-fix existing slates, replacing broken slates as required using 'matching natural slates'. We are concerned that these replacement slates should indeed be matching, which, we understand, would mean natural Welsh slate. This would achieve consistency of appearance, important in a Listed Building, but also consistency of weathering. We understand that the Crown Estate requires the use of Welsh slate for repairs to the roofs of its Listed Buildings in the area.</p> <p>Richard Simpson FSA Chair</p>
