



FOR CONTINUATION REFER TO DRAWING No. P5-DES-001-05-DR-E-1004

- NOTES**
1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, SPECIFICATIONS AND SCOPE OF WORKS.
 2. THIS DRAWING IS TO BE READ FOR SERVICES INFORMATION ONLY.
 3. ALL SIZES ARE IN MM.
 4. DO NOT SCALE FROM THIS DRAWING; ALL DIMENSIONS TO BE VERIFIED FROM SITE MEASUREMENT PRIOR TO COMMENCING WORKS.
 5. REFER TO LEGEND DRAWING No. P5-DES-000-XX-DR-E-0001.
 6. ALL DETAILS TO BE CONFIRMED.
 7. FINAL LOCATIONS AND QUANTITY OF ILLUMINATED EMERGENCY EXIT SIGNS TO BE AGREED WITH BCO.
 8. REFER TO SEPARATE TECHNICAL SUBMISSION FOR LIGHTING CONTROL PHILOSOPHY.
 9. REFER TO ARCHITECT'S C-SHEETS FOR POSITIONS OF LIGHT SWITCHES AND ILLUMINATED ROOM SIGNS IN CORRIDORS.
 10. DUEL SUPPLIES TO CLINICAL SPACES OMITTED AS PER AGREED VE.

LEGEND

REFERENCE DRAWINGS

P02	COMMENTS INCORPORATED.	NOV 2018	Y.L.
P01	PRELIMINARY ISSUE	DEC 2017	M.A.
REV	DESCRIPTION	DATE	BY



CLIENT



PROJECT

UCLH - PHASE 5

TITLE

ELECTRICAL SERVICES
FIFTH FLOOR - SOUTH
LIGHTING LAYOUT

DISCIPLINE

ELECTRICAL

STATUS

APPROVAL

DRAWN BY M.A.	CHECKED BY A.D.	SIZE A0
JOB No. P5	SCALE 1:50	DATE 26/04/2018
DRAWING No. P5-DES-001-05-DR-E-1003	REV. P02	

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

READERS OF THIS DRAWING:
ALL EFFORTS HAVE BEEN TAKEN BY DORNAN TO DESIGN OUT SIGNIFICANT HAZARDS WITHIN THE DESIGN RISK ASSESSMENT PROCESS. IT IS OUR OPINION THAT THE HAZARDS IDENTIFIED BELOW CANNOT BE DESIGNED OUT BY US GIVEN THE CONSTRAINTS OF THE BRIEF AND ARE HIGHLIGHTED SO THAT OTHER MEANS CAN BE DEVELOPED TO MITIGATE THE RESIDUAL RISK IDENTIFIED.

NO SIGNIFICANT HAZARDS ASSOCIATED WITH THIS DRAWING

IT IS ASSUMED THAT A COMPETENT MAINTENANCE CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD FORESEEABLE RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILED WITHIN THIS DRAWING.