

**NOTES**

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, SPECIFICATIONS AND SCOPE OF WORKS.
2. THIS DRAWING IS TO BE READ FOR SERVICES INFORMATION ONLY.
3. ALL SIZES ARE IN MM.
4. DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS TO BE VERIFIED FROM SITE MEASUREMENT PRIOR TO COMMENCING WORKS.
5. REFER TO LEGEND DRAWING No. P5-DES-000-XX-DR-E-0001.
6. ALL DETAILS TO BE CONFIRMED.
7. FINAL LOCATIONS AND QUANTITY OF ILLUMINATED EMERGENCY EXIT SIGNS TO BE AGREED WITH BCO.
8. REFER TO SEPARATE TECHNICAL SUBMISSION FOR LIGHTING CONTROL PHILOSOPHY.
9. REFER TO ARCHITECT'S C-SHEETS FOR POSITIONS OF LIGHT SWITCHES AND ILLUMINATED ROOM SIGNS IN CORRIDORS.
10. DUEL SUPPLIES TO CLINICAL SPACES OMITTED AS PER AGREED VE.

**LEGEND**

**REFERENCE DRAWINGS**

PO4	ARCHITECTURAL LAYOUT UPDATED.	JAN 2019	Y.L.
PO3	PRELIMINARY ISSUE	NOV 2018	Y.L.
PO2	REVISED TO MAKE COMMENTS.	APR 2018	M.A.
PO1	PRELIMINARY ISSUE	DEC 2017	M.A.
REV	DESCRIPTION	DATE	BY



CLIENT  
PROJECT  
UCLH - PHASE 5

TITLE  
ELECTRICAL SERVICES  
SIXTH FLOOR - ROOF - SOUTH  
LIGHTING LAYOUT

DISCIPLINE <b>ELECTRICAL</b>			
STATUS <b>APPROVAL</b>			
DRAWN BY M.A.	CHECKED BY A.D.	SIZE A0	
JOB No. P5	SCALE 1:50	DATE DEC 2017	
DRAWING No. P5-DES-001-R6-DR-E-1003	REV. P04		



FOR CONTINUATION REFER TO DRAWING No. P5-DES-001-R6-DR-E-1004

**SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION**  
READERS OF THIS DRAWING:  
ALL REPORTS HAVE BEEN TAKEN BY COSH TO DESIGN OUT SIGNIFICANT HAZARDS WITHIN THE DESIGN RISK ASSESSMENT PROCESS. IT IS OUR OPINION THAT THE HAZARDS DETAILLED BELOW CANNOT BE DESIGNED OUT BY US GIVEN THE CONSTRAINTS OF THE BRIEF AND ARE HIGHLIGHTED SO THAT OTHER MEASURES CAN BE DEVELOPED TO MITIGATE THE RESIDUAL RISKS IDENTIFIED.  
**NO SIGNIFICANT HAZARDS ASSOCIATED WITH THIS DRAWING**

IT IS ASSUMED THAT A COMPETENT MACE CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD FORESIGHTS & RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILLED WITHIN THIS DRAWING.