

# File Note

# ARUP

13 Fitzroy Street  
London  
W1T 4BQ  
United Kingdom  
www.arup.com

t +44 20 7636 1531  
d +44 20 775 [Click here to enter extn](#)

---

Project title Middlesex Annex Site

Job number

250794-00

---

cc

File reference

---

Prepared by CB

Date

15 April 2019

---

Subject Cooling System Efficiency - Workhouse

---

The present file note has been produced with the intent of providing information on the proposed cooling system efficiency that has been designed for the Workhouse. That information is required to discharge the planning Condition 17.

*Condition 17 - Prior to works to the listed building being carried out, full details of the TM52 overheating assessment should be provided to demonstrate that the residential units do not overheat without being reliant on mechanical cooling. The applicant should demonstrate that the Mayor's cooling hierarchy has been followed and that overheating risk has been reduced as far as possible, and that active cooling is not proposed unless it can be demonstrated it is required and that all other measures have been considered first. **Where active cooling is required, details demonstrating the efficiency of the system should be provided to the Council.***

The cooling in the Workhouse apartments is provided by FCU located in the ceiling void of each habitable room (bedroom, kitchen-livingroom). The CHW feeding the FCU is produced by two air cooled chillers located on the New Building's roof. As stated in the Equipment Datasheet submitted for Stage 4 (see Appendix 1) the Chillers have an EER of 3.3 and SEER of 4.99.

Regarding the FCU efficiency the SFP is between 0.13 and 0.21 with only one FCU having an SFP of 0.32 (see Appendix 2).

---

## DOCUMENT CHECKING (not mandatory for File Note)

	Prepared by	Checked by	Approved by
Name	CB	MK	
Signature			

# File Note

250794-00

15 April 2019

---

## Appendix : Chillers and FCU EDSs

---

Job Title:	MSA-Plantroom			Job Number:	250794
Job Stage:	Stage 4	Status:	Stage 4	Made by:	VS
Revision:		Date:	30/04/2018	Checked by:	DB
Revision Description:					

### General Data

Unit Reference	CH/08/01 & 02
Quantity	2
Type	Inverter Screw c/w VVR
Location	Roof plant
System	Chilled water

### Performance Data

		Required	Offered			Required	Offered
Cooling Capacity	kW	240		Refrigerant Type		R134a	
Site Altitude	m			Refrigerant Charge	kg	40	
Chilled Water Flow Rate	kg/s	9.6		EER		3.333	
Maximum CHW Flow Rate	kg/s	9.6		SEER		4.99	
Minimum CHW Flow Rate	kg/s	3.2		Coefficient of Performance	COP		
CHW Leaving Temperature	°C	7		Number of Refrigerant Circuits		1	
CHW Entering Temperature	°C	13		Number of Control Stages		Stepless	
Min CHW Leaving Temperature	°C	7		Min Cooling Capacity Control Step		34%	
Max CHW Entering Temperature	°C	26		Type of Expansion Valve		EEV	
Min CHW System Contents	litres	TBC		Noise Level (Lp) @3m	dB(A)	63.0	

### Evaporator

Number of Evaporators		1	
Pressure Drop	kPa	11.9	
Max Operating Pressure	bar (g)	10.0	
Test Pressure	bar (g)	15.0	
Fouling Factor	m <sup>2</sup> K/w	0.000	
Water Contents	litres	38	
CHW Antifreeze Solution	%		
Type		Plated heat exchanger	

Shell Material		Alu	
Tube Material		Cu	
Insulation Material		Armaflex	
Insulation Thickness	mm	20	
CHW Connection Type		Victaulic	
CHW Connection Size Ø	mm	114.3	
Drain Connection Ø	mm	25.4	
LP Relief Valve Setting	bar (g)	TBC	

### Condenser

Design Air Entering Temperature	°C	35	
Max Air Entering Temperature	°C	45	
Min Air Entering Temperature	°C	-3.3	
Number of Fans		6	
Fan Type		Direct propeller	
Fan Minimum Efficiency	%		
Fan Air Flow Rate	l/s	22664	

Fan External Pressure	Pa	100	
Max Fan Speed	rpm	700	
Fan Size	mm	800	
Method of Head Pressure Control		Inverter	
Type		MCH	
Tube / Fin Material		Alu	
Protective Coating		Blue Acrylic	
HP Relief Valve Setting	bar (g)	TBC	

### Compressors

Compressor Type	Inv screw VVR	
Number of Compressors	1	

Compressor Motor Speed	rpm	Variable	
Max Compressor Starts / Hour		3	
Max Allowable Pressure (Ps)	bar (g)		

### Unit

Unit Casing Material	RAL 7044	
Unit Casing Finish / Colour	RAL 7044	

Unit Operating Weight	kg	2559	
-----------------------	----	------	--

### Dimensional Data

Overall Length	mm	3183	
Overall Width	mm	2258	

Overall Height	mm	2483	
----------------	----	------	--

Job Title:	MSA-Plantroom			Job Number:	250794
Job Stage:	Stage 4	Status:	Stage 4	Made by:	VS
Revision:		Date:	30/04/2018	Checked by:	DB
Revision Description:					

### Electrical Data

		Required	Offered			Required	Offered
Main Power Supply	V/Ø/Hz	400/3/50		Compressor Absorbed Power	kW	67.81	
Main Power Supply Source				Compressor Motor Rating	kW	75	
Auxillary Power Supply	V/Ø/Hz			Compressor Running Current	A	104	
Auxillary Power Supply Source		None		Compressor Starting Current	A	0	
Unit Max Absorbed Power	kW	72.61		Condenser Fan Input Power	kW	15.6	
Unit Max Running Current	A	166		Condenser Fan Motor Rating	kW	4.8	
Unit Max Starting Current	A	0		Crankcase Heater Rating	W	300	
Unit Upstream Protection Device				Evaporator Heater Rating	W	300	
Unit Max In Rush Current	A/5msec			Unit IP Rating		IP54	
Unit Max Fault Level	kA 1sec			Local Power Factor Correction		>0.95	
Compressor In Rush Current	A/5msec			Power Factor		>0.95	
Compressor Motor Start Method		Inverter					

### Noise & Vibration Data

		Max Radiated Sound Pressure Level (Lp) dB							
		63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
Required		68	65	65	68	63	58	50	43
Offered									

		Required	Offered			Required	Offered
Compressor Anti Vibration Mount Type		Required		Unit Anti Vibration Mount Type		Required	
Compressor AVM Static Deflection	mm			Unit AVM Static Deflection	mm	25	

### Access

		Required	Offered			Required	Offered
Min Side Clearance	mm	1800		Largest Component		Compressor	
Min End Clearance	mm	1500		Length of Largest Component	mm	1200	
Min Top Clearance	mm	1500		Width of Largest Component	mm	400	
Tube Withdrawal Clearance	mm	1000		Height of Largest Component	mm	400	
Heaviest Component		Compressor					
Weight of Heaviest Component	kg	1000					

### Safety & Diagnostics

	Required	Offered		Required	Offered
High Refrigerant Pressure Cut Out	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Suction Temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Low Refrigerant Pressure Cut Out	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Discharge Temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Low Suction Temperature Cut Out	<input checked="" type="checkbox"/>	<input type="checkbox"/>	CHW Entering Temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Low Oil Pressure Cut Out	<input checked="" type="checkbox"/>	<input type="checkbox"/>	CHW Leaving Temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Water Flow Pump Interlock	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Nos Compressors Operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Oil Pressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Compressor Operating Hours	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Suction Pressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Fault History	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Discharge Pressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>			

### Control & Monitoring

	Required	Offered		Required	Offered
Microprocessor Controls	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Leaving Chilled Water Control	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Diagnostics	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Automatic Lead/Lag Compressor Control	<input type="checkbox"/>	<input type="checkbox"/>
Master Sequencer Controls	<input type="checkbox"/>	<input type="checkbox"/>	Chiller Flow Proving Switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Job Title:	MSA-Plantroom			Job Number:	250794
Job Stage:	Stage 4	Status:	Stage 4	Made by:	VS
Revision:		Date:	30/04/2018	Checked by:	DB
Revision Description:					

### Outputs to BMS

Chiller Run Status Volt Free Contact  
Common Alarm Volt Free Contact  
BACnet/Modbus Data link

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

### Inputs from BMS

Chiller Enable/Disable  
Sequencer Enable/Disable  
CHW Temperature Reset (0-10VDC)  
Power Demand Limit Control

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

Serial Data Link Protocol

Required  
Offered


### Accessories

Compressor Isolating Valves  
Low Ambient Temperature Start  
Condenser Coil Wind Baffles  
Condenser Coil Protection Guards  
Corrosion Resistant Coated Coils  
Special Anti Corrosion Treatment  
Power Supply Isolator  
Compressor Soft Start  
Crankcase Heater Transformer

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Low Noise Condenser Fans  
Compressor Attenuator Enclosures  
High Pressure Condenser Fans  
Works Fitted Physical Protection Kit

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

### Testing

Performance Type Tests  
Works Performance Tests  
Site OEM Performance Testing

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

### Samples

Required Offered

<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

### Works Performance Tests

Chilled Water Flow Rate  
Chilled Water Flow & Return Temperatures  
Evaporator Pressure Drop  
Condenser Coil Air On Temperature  
Condenser Air Off Temperature  
Liquid line Refrigerant Temperature  
Evaporator Refrigerant Pressure  
Condenser Refrigerant Pressure  
Oil Pressure  
Compressor Voltage (each)  
Compressor Running Current (each)  
Voltage (incoming terminals)  
Running Current (machine)  
Starting Inrush Current  
Total Absorbed Power  
Power Factor  
Operation of All Safety Devices  
Provision of External Interfaces

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

### Full Load Test

100% Load Test  
Duration of each Load Test (hours)  
Measurement Interval (minutes)  
Minimum No. of Measurement Intervals

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
1	<input type="checkbox"/>
10	<input type="checkbox"/>
6	<input type="checkbox"/>

### Minimum Load Test

Minimum Load Test  
Duration of each Load Test (hours)  
Measurement Interval (minutes)  
Minimum No. of Measurement Intervals

Required Offered

<input checked="" type="checkbox"/>	<input type="checkbox"/>
1	<input type="checkbox"/>
15	<input type="checkbox"/>
4	<input type="checkbox"/>

### Part Load Test

90% Load Test  
75% Load Test  
66% Load Test  
50% Load Test  
33% Load Test  
25% Load Test  
Duration of Minimum Load Test (minutes)

Required Offered

<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
60	<input type="checkbox"/>

Under Capacity Tolerance wrt Design (-%)

0	<input type="checkbox"/>
---	--------------------------

Job Title:	<b>MSA-Plantroom</b>			Job Number:	<b>250794</b>
Job Stage:	<b>Stage 4</b>	Status:	<b>Stage 4</b>	Made by:	<b>VS</b>
Revision:		Date:	<b>30/04/2018</b>	Checked by:	<b>DB</b>
Revision Description:					

Over Capacity Tolerance wrt Design (+%)

Full Noise & Vibration Test

Job Title:	<b>MSA-Plantroom</b>			Job Number:	<b>250794</b>
Job Stage:	<b>Stage 4</b>	Status:	<b>Stage 4</b>	Made by:	<b>VS</b>
Revision:		Date:	<b>30/04/2018</b>	Checked by:	<b>DB</b>
Revision Description:					

### Works Performance Tests

- 1 Carry out performance tests at the manufacturer's works or at an agreed testing facility.
- 2 Demonstrate:
  - a Compliance with the Specification.
  - b Thermal performance specified.
  - c Operation and control throughout the stated operating range.
  - d Noise & vibration performance specified.
- 3 Provide a complete and precise Test Method Statement. Include method for measuring average condenser air on and off temperatures across coils.
- 4 Carry out tests in a safe working environment.
- 5 Provide test instruments necessary to accurately record measurements, attached or adjacent to the machine.
- 6 Provide copies of the calibration certificates for test instruments before testing..
- 7 Provide a PC for gathering data to allow instantaneous recordings to be made.
- 8 Confirm all details of the performance tests with the Tender, including location of test.
- 9 Simulate design chilled water flow rate, chilled water temperatures, condenser air temperatures and site electrical characteristics at full and part load conditions.
- 10 Measure and record full and part load test results at specified intervals.
- 11 Carry out load tests under steady state conditions and specified design conditions.
- 12 Demonstrate design chilled water leaving temperature is maintained at full and all part load conditions.
- 13 Demonstrate minimum load tests to manufacturers stated minimum load unless otherwise specified.
- 14 Demonstrate all safety devices operate correctly at manufacturers' recommended set points on completion of thermal performance tests.
- 15 Carry out Works Tests to BS EN 14511.
- 16 Demonstrate design cooling capacity can be achieved with tolerances of -0% and +5%.
- 17 Noise tests shall be to BS EN ISO 3744:1995 and the Specification.
- 18 Rectify any defects or items of non compliance with the Specification, retest and redemonstrate at no extra cost.
- 19 Record test data on manufacturers test sheets demonstrating specified performance.
- 20 Submit a complete Test Report

### Manufacturer

Manufacturer  
Model Reference  
Contact Name  
Telephone Number  
Fax Number  
E-mail Address  
Internet Address

Preferred	Alternative	Alternative
Daikin Applied		
EWAD240TZ-XR B1		
Bob Stevens		
+44 345 5652700		
Bob.Stevens@daikinapplied.uk		

Job Title:	MSA-Plantroom		Job Number:	250794	
Job Stage:	Stage 4	Status:	Stage 4	Made by:	VS
Revision:		Date:	30/04/2018	Checked by:	DB
Revision Description:					

### Additional Information

### Comments

- 1 *This equipment data sheet **must** be read in conjunction with all other parts of the Specification, including:  
the Technical Introduction  
the Materials and Workmanship Specification  
the Particular Specification.*
- 2 *Type test data shall be provided to demonstrate that the equipment performs to the required standards.  
Chillers shall be commissioned by the Specialist*
- 3 *Manufacturer and test in accordance with  
CIBSE Commissioning Code R.*
- 4 *All inputs/outputs to be wired to numbered terminals within the control panel.  
All alarm volt free contacts shall be fail safe. Contacts shall be normally open, closed when healthy, open on alarm or loss of power*
- 6 *All volt free contacts to be rated at 3A inductive at 230 VAC.*
- 7 *Selection based upon EN14511-3:2013 Nett Performance*



Job Title:	MSA-Listed Building		Job Number:	250794	
Job Stage:	Stage 4	Status:	Stage 4	Made by:	CB
Revision:		Date:	30/04/2018	Checked by:	VS
Revision Description:					

### General Data

Entering Air Design Conditions:		
Season	Temperature db°C	Temperature wb°C
Summer	24.0	17.0
Winter	22.0	

Cooling Design Conditions:	
Flow Temp. °C	Return Temp. °C
10.0	16.0

Heating Design Conditions:	
Flow Temp. °C	Return Temp. °C
60.0	40.0

### Construction Data

Casing Material	
Casing Thickness	mm
Casing Finish / Colour	
Coil Tube/Fin Material	
Fan Type	
Coil Connection Type	

Filter Group & Class  
Filter Test Standard  
Coil Test Pressure  
Electrical Supply

Required	Offered
BSEN 779	
bar (g)	
V/Ø/Hz	240/1/50

### Accessories

	Required	Offered
Discharge Plenum (for Highwall series)	<input type="checkbox"/>	<input type="checkbox"/>
Insulated Drip Tray	<input type="checkbox"/>	<input type="checkbox"/>
Octopus Box (for Highline Series)	<input type="checkbox"/>	<input type="checkbox"/>

Condensate Tray Material  
Filter Medium  
Access Arrangement  
Inlet Location  
Discharge Location


### Controls

	Required	Offered
Wall Mounted Speed Selection Switch (for YMH series)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Room Temperature Sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Return Air Temperature Sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature Controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Controls Enclosure, Fuses, Relays	<input type="checkbox"/>	<input type="checkbox"/>
Low Voltage Transformer	<input type="checkbox"/>	<input type="checkbox"/>
Remote Start/Stop Control	<input type="checkbox"/>	<input type="checkbox"/>
BMS Addressable Controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Control Valves & Actuators	<input type="checkbox"/>	<input type="checkbox"/>

Controls Manufacturer **Required**

### Testing

	Required	Offered
Performance Type Tests	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Works Performance Tests	<input type="checkbox"/>	<input type="checkbox"/>
Site OEM Performance Tests	<input type="checkbox"/>	<input type="checkbox"/>

### Samples

	Required	Offered
Type Samples	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>

### Works Performance Tests

	Required	Offered
Noise Performance Tests	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Duty Performance Tests	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Functional Performance Tests

Required	Offered
<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>

### Manufacturer

Manufacturer	
Contact Name	
Telephone Number	
Fax Number	
E-mail Address	
Internet Address	

Preferred	Alternative	Alternative
Diffusion	Equal or Approved	

### Additional Information

- Type test data shall be provided to demonstrate that the equipment performs to the required standards.
- Apartment FCUs to be complete with gravity condensate drain
- All fan coil units shall be provided spare set of filters to the building operator prior to building hand over.
- Values in (xx) include the FCU's performance for maximum cooling capacity required

- Discharge in-duct values are givenen "per spigot"
- When attenuation is required it must have the following insertion loss
 

Octave Band Frequency (Hz)							
63	125	250	500	1K	2K	4K	8K
3	5	7	11	13	15	8	3



FCU Reference	Location	Quantity	Model Reference	Attenuator	Octopus Box	Fan				Cooling Coil				Heating Coil			Dimensions			
						SFP W/s	Air Flow Rate l/s	Fan Speed	NR	Total Capacity kW	Sensible Capacity kW	Flow Rate l/s	Pressure ΔPa	Total Capacity kW	Flow Rate l/s	Pressure ΔPa	Height mm	Length mm	Width mm	
Required Offered	FCU/M03/01	Bed 1	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.17)	66 (75)	uLow (xLow)	25 (27)	0.89 (1.0)	0.79 (0.9)	0.040		0.76	0.009		270	858	882
Required Offered	FCU/M03/02	Bed 2	1	H27Aec-WHCH-06/1 * FR+CP	N	Y (Ø247)	0.16 (0.19)	66 (92)	uLow (Low)	25 (30)	0.89 (1.2)	0.79 (1.1)	0.048		0.67	0.008		270	858	882
Required Offered	FCU/M03/03	Kitchen/Living	1	H27Aec-WHCH-12/2 * FR+CP	N	Y (Ø247)	0.13	158	Low	30	2.1	1.9	0.084		1.28	0.015		270	1233	882
Required Offered	FCU/M04/01	Bed 1	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.20)	66 (108)	uLow (Low+1)	25 (31)	0.89 (1.4)	0.79 (1.3)	0.005		1.17	0.014		270	858	882
Required Offered	FCU/M04/02	Bed 2	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.17)	66 (67)	uLow (xLow)	25 (27)	0.89 (1.0)	0.79 (0.8)	0.040		0.61	0.007		270	858	882
Required Offered	FCU/M04/03	Bed 3	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.19)	66 (83)	uLow (Low)	25 (30)	0.89 (1.1)	0.79 (1.0)	0.044		0.60	0.007		270	858	882
Required Offered	FCU/M04/04	Kitchen/Living	1	H27Aec-WHCH-12/2 * FR+CP	Y	Y (Ø247)	0.16	217	Low+3	30	2.9	2.6	0.116		1.91	0.023		270	1233	1200
Required Offered	FCU/M05/01	Bed 1	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.19)	66 (92)	uLow (Low)	25 (30)	0.89 (1.2)	0.79 (1.1)	0.048		0.6	0.007		270	858	882
Required Offered	FCU/M05/02	Kitchen/Living	1	H27Aec-WHCH-12/2 * FR+CP	N	Y (Ø247)	0.13	175	Low	30	2.3	2.1	0.092		1.48	0.018		270	1233	882
Required Offered	FCU/M06/01	Bed 1	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.19)	66 (83)	uLow (Low)	25 (30)	0.89 (1.1)	0.79 (1.0)	0.044		0.52	0.006		270	858	882
Required Offered	FCU/M06/02	Kitchen/Living	1	H27Aec-WHCH-09/1 * FR+CP	N	Y (Ø247)	0.18	117	Low	30	1.5	1.4	0.060		0.71	0.008		270	1078	882
Required Offered	FCU/M07/01	Bed 1	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.19)	66 (83)	uLow (Low)	25 (30)	0.89 (1.1)	0.79 (1.0)	0.044		0.59	0.007		270	858	882
Required Offered	FCU/M07/02	Bed 2	1	H27Aec-WHCH-06/1 * FR+CP	N	N	0.16 (0.19)	66 (75)	uLow (Low)	25 (30)	0.89 (1.1)	0.79 (0.9)	0.044		0.47	0.006		270	858	882
Required Offered	FCU/M07/03	Kitchen/Living	1	H27Aec-WHCH-13/2 * FR+CP	N	Y (Ø247)	0.13	200	Low	30	2.6	2.4	0.104		1.41	0.017		270	1411	882
Required Offered	FCU/M08/01	Bed 1	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (83)	uLow (Low)	25 (30)	0.82 (1.1)	0.75 (1.0)	0.044		0.56	0.007		170	1213	795
Required Offered	FCU/M08/02	Kitchen/Living	1	H17Aec-WHCH-SS17/3 * FR+CS	N	Y (Ø197)	0.20	158	Low	30	2.0	1.9	0.080		1.31	0.016		210	1639	934
Required Offered	FCU/M09/01	Bed 1	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (83)	uLow (Low)	25 (30)	0.82 (1.1)	0.75 (1.0)	0.044		0.52	0.006		170	1213	795
Required Offered	FCU/M09/02	Kitchen/Living	1	H17Aec-WHCH-SS17/2 * FR+CS	N	Y (Ø197)	0.21	108	Low	30	1.4	1.3	0.056		0.67	0.008		210	1239	934
Required Offered	FCU/M10/01	Bed 1	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (83)	uLow (Low)	25 (30)	0.82 (1.1)	0.75 (1.0)	0.044		0.57	0.007		170	1213	795
Required Offered	FCU/M10/02	Bed 2	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (75)	uLow (Low)	25 (30)	0.82 (1.0)	0.75 (0.9)	0.040		0.48	0.006		170	1213	795
Required Offered	FCU/M10/03	Kitchen/Living	1	H17Aec-WHCH-SS17/3 * FR+CS	Y	Y (Ø197)	0.21	175	Low+1	30	2.3	2.1	0.092		1.26	0.015		210	1639	1200
Required Offered	FCU/M11/01	Bed 1	1	HW26Aec-WVCH-06/1	N/A	N/A	0.20 (0.25)	72 (117)	uLow (Low+3)	20 (28)	0.97 (1.5)	0.86 (1.4)	0.056		0.85	0.010		2110	804	275
Required Offered	FCU/M11/02	Bed 2	1	HW26Aec-WVCH-06/1	N/A	N/A	0.20 (0.21)	72 (83)	uLow (xLow+1)	20 (23)	0.97 (1.1)	0.86 (1.0)	0.040		0.42	0.005		2110	804	275
Required Offered	FCU/M11/03	Kitchen	1	H17Aec-WHCH-SL09/2 * FR+CS	N	Y (Ø197)	0.21	83	Low	30	1.2	1.0	0.004		0.28	0.003		211	1026	835
Required Offered	FCU/M11/03	Living	2	H27Aec-WHCH-06/1 * FR+CP	N	Y (Ø247)	0.19	84	Low	30	1.1	1.0	0.044		0.815	0.010		270	858	882
Required Offered	FCU/M12/01	Bed 1	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (83)	uLow (Low)	25 (30)	0.82 (1.1)	0.75 (1.0)	0.040		0.43	0.005		170	1213	795
Required Offered	FCU/M12/02	Bed 2	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (83)	uLow (Low)	25 (30)	0.82 (1.0)	0.75 (0.9)	0.036		0.43	0.005		170	1213	795
Required Offered	FCU/M12/03	Kitchen/Living	1	HW26Aec-WVCH-09/2	N/A	N/A	0.32	158	Low+3	28	2.1	1.9	0.008		1.06	0.013		211	1024	275
Required Offered	FCU/M13/01	Bed 1	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (92)	uLow (Low)	25 (30)	0.82 (1.2)	0.75 (1.1)	0.040		0.55	0.007		170	1213	795
Required Offered	FCU/M13/02	Bed 2	1	H17Aec-WHCH-SL09/2 * FR+CS	N	N	0.21	63 (92)	uLow (Low)	25 (30)	0.82 (1.2)	0.75 (1.1)	0.040		0.46	0.006		170	1213	795
Required Offered	FCU/M13/03	Kitchen	1	H17Aec-WHCH-SL09/2 * FR+CS	N	Y (Ø197)	0.21	83	Low	30	1.2	1.0	0.048		0.38	0.005		211	1026	835
Required Offered	FCU/M13/04	Living	2	H27Aec-WHCH-06/1 * FR+CP	Y	Y (Ø247)	0.2	109	Low	30	1.4	1.3	0.056		1.00	0.012		270	858	1200

FCU Reference	Model Reference	Attenuator	Inlet & Case Radiated Air								Discharge Duct Radiated								Discharge In-duct								
			Free Field / In Duct Sound Power Level @ Lw dB								Free Field / In Duct Sound Power Level @ Lw dB								Free Field / In Duct Sound Power Level @ Lw dB								
			63 Hz	125 Hz	250 Hz	500 Hz	1 Hz	2 Hz	4 Hz	8 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1 Hz	2 Hz	4 Hz	8 Hz	63 Hz	125 Hz	250 Hz	500 Hz	1 Hz	2 Hz	4 Hz	8 Hz	
FCU/M03/01	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Required
FCU/M03/02	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Offered
FCU/M03/03	H27Aec-WHCH-12/2 * FR+CP	N	46	49	45	42	35	29	22	19	43	42	43	40	35	26	18	15	53	48	45	39	33	23	15	12	Required
FCU/M04/01	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Offered
FCU/M04/02	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Required
FCU/M04/03	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Offered
FCU/M04/04	H27Aec-WHCH-12/2 * FR+CP	Y	47	53	48	46	40	35	28	21	45	45	46	42	40	31	24	17	55	51	48	41	38	28	21	14	Required
FCU/M05/01	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Offered
FCU/M05/02	H27Aec-WHCH-12/2 * FR+CP	N	46	49	45	42	35	29	22	19	43	42	43	40	35	26	18	15	53	48	45	39	33	23	15	12	Required
FCU/M06/01	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Offered
FCU/M06/02	H27Aec-WHCH-09/1 * FR+CP	N	42	52	45	44	41	37	29	22	41	44	45	44	42	33	26	17	51	50	47	43	40	30	23	14	Required
FCU/M07/01	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Offered
FCU/M07/02	H27Aec-WHCH-06/1 * FR+CP	N	41	46	43	42	33	28	19	21	45	45	42	38	36	24	19	23	55	51	44	37	34	21	16	20	Required
FCU/M07/03	H27Aec-WHCH-13/2 * FR+CP	N	44	51	46	44	39	33	26	21	47	43	44	43	38	29	21	16	55	47	44	40	34	24	16	11	Offered
FCU/M08/01	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Required
FCU/M08/02	H17Aec-WHCH-SS17/3 * FR+CS	N	51	46	45	43	37	26	21	21	49	40	44	45	39	31	23	15	61	46	45	43	34	25	17	9	Offered
FCU/M09/01	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Required
FCU/M09/02	H17Aec-WHCH-SS17/2 * FR+CS	N	44	43	43	43	41	32	20	19	51	38	41	44	38	31	22	15	62	44	43	41	33	25	16	9	Offered
FCU/M10/01	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Required
FCU/M10/02	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Offered
FCU/M10/03	H17Aec-WHCH-SS17/3 * FR+CS	Y	52	48	46	44	39	28	22	21	49	42	46	47	42	32	24	16	61	49	47	44	37	26	19	10	Required
FCU/M11/01	HW26Aec-WVCH-06/1	N/A	42	41	31	24	17	15	18	19	42	36	32	25	22	14	18	18	55	44	35	26	22	14	18	18	Offered
FCU/M11/02	HW26Aec-WVCH-06/1	N/A	42	41	31	24	17	15	18	19	42	36	32	25	22	14	18	18	55	44	35	26	22	14	18	18	Required
FCU/M11/03	H17Aec-WHCH-SL09/2 * FR+CS	N	46	43	41	42	39	30	20	19	46	36	39	41	37	27	16	14	58	42	40	39	32	22	10	8	Required
FCU/M11/03	H27Aec-WHCH-06/1 * FR+CP	N	43	47	44	43	34	29	21	21	46	46	43	38	37	26	21	24	56	52	45	37	35	23	18	21	Offered
FCU/M12/01	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Required
FCU/M12/02	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Offered
FCU/M12/03	HW26Aec-WVCH-09/2	N/A	44	45	37	28	21	16	19	22	36	42	40	33	27	16	21	21	47	48	43	34	28	16	21	21	Required
FCU/M13/01	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Required
FCU/M13/02	H17Aec-WHCH-SL09/2 * FR+CS	N	46	41	39	40	37	27	19	19	45	36	37	39	34	23	13	13	56	42	38	36	29	18	7	7	Offered
FCU/M13/03	H17Aec-WHCH-SL09/2 * FR+CS	N	46	43	41	42	39	30	20	19	46	36	39	41	37	27	16	14	58	42	40	39	32	22	10	8	Required
FCU/M13/04	H27Aec-WHCH-06/1 * FR+CP	Y	44	49	46	45	37	33	26	21	47	49	46	40	39	29	26	25	57	55	48	39	37	26	23	22	Offered