



NOTES

- DO NOT SCALE FROM THIS DRAWING.
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS ISSUED BY THE ENGINEER.
- ALL DIMENSIONS TO BE CHECKED ON SITE AND THE ENGINEER NOTIFIED OF ANY DISCREPANCIES PRIOR TO COMMENCEMENT OF WORK.
- THE POSITION OF ALL EQUIPMENT INDICATED ON THIS DRAWING IS APPROXIMATE. THE EXACT POSITION OF ALL EQUIPMENT TO BE AGREED WITH THE ENGINEER PRIOR TO COMMENCING WORKS.

LEGEND

- IN-GROUND BOLLARD WITH ROOT
- SURFACE BULKHEAD KCO IP65 400mm DIAMETER, 20W, SILVER FINISH, TYPE K4H42/4K5, CAST ALUMINIUM WITH INJECTION MOLDED BASE (E DENOTES EMERGENCY VERSION)
- WALL MOUNTED BULKHEAD KCO IP65 400mm DIAMETER, 10W, SILVER FINISH, TYPE K4H40/4K5, CAST ALUMINIUM WITH INJECTION MOLDED BASE AND HOOD TO REDUCE LIGHT POLLUTION (E DENOTES EMERGENCY VERSION)
- RECESSED BRICK LIGHT INTEGRATED INTO LOW LEVEL PLANTER FEATURE
- SMALL 4W BULKHEAD LIGHT ABOVE DOORWAYS AS THORLUX 'REALTA MICRO', (E DENOTES EMERGENCY VERSION)
- DISTRIBUTION BOARD
- TIME CLOCK
- PHOTOCELL
- RUN-DOWN TIME SWITCH
- IP RATED PRESENCE DETECTOR

T2	A.C.	LUMINAIRES ADDED AND CIRCUITS RE-ARRANGED TO MEET BREEM AND SED REQUIREMENTS	T.M.	MAR. 2019
T1	N.W.	TENDER ISSUE	A.C.	JAN. 2019

CLIENT
GALLIFORD TRY PARTNERSHIP

PROJECT
CHARLIE RATCHFORD, EXTRA CARE
CROSSLAND ROAD
CAMDEN, LONDON

TITLE
EXTERNAL AREAS
LIGHTING LAYOUT



Glasgow 0141 552 2463	London 0207 953 0202	Manchester 0161 747 4901
DRAWN J.D.K. / A.C.	CHECKED T.M.	APPROVED D.MCN.
SCALE 1:100 @ A0	DATE DEC. 2018	REVISION T2
DRAWING NO. 20552-E-312		TENDER