

**From:** [REDACTED]  
**Sent:** 24 April 2019 14:52  
**To:** Planning [REDACTED]  
**Subject:** Informative Only Planning Application - 2018/4877/P

London Borough of Camden Our DTS Ref: 100347  
Camden Town Hall Your Ref: 2018/4877/P  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

24 April 2019

Dear Sir/Madam

Re: 65-69, HOLMES ROAD, LONDON, NW5 3AN

#### WASTE COMMENT

Thames Water requests that the Applicant should incorporate within their proposal, protection to the property by installing a positive pumped device (or equivalent reflecting technological advances) to avoid the risk of backflow at a later date, on the assumption that the sewerage network may surcharge to ground level during storm conditions. Fitting only a non-return valve could result in flooding to the property should there be prolonged surcharge in the public sewer. If as part of the basement development there is a proposal to discharge ground water to the public network, this would require a Groundwater Risk Management Permit from Thames Water. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing [wwriskmanagement@thameswater.co.uk](mailto:wwriskmanagement@thameswater.co.uk). Application forms should be completed on line via [www.thameswater.co.uk/wastewaterquality](http://www.thameswater.co.uk/wastewaterquality)

Thames Water recommends the installation of a properly maintained fat trap on all catering establishments. We further recommend, in line with best practice for the disposal of Fats, Oils and Grease, the collection of waste oil by a contractor, particularly to recycle for the production of bio diesel. Failure to implement these recommendations may result in this and other properties suffering blocked drains, sewage flooding and pollution to local watercourses.

As you are redeveloping a site, there may be public sewers crossing or close to your development. If you discover a sewer, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes. <https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development/Working-near-or-diverting-our-pipes>.

Thames Water would advise that with regard to waste water network and waste water process


infrastructure capacity, we would not have any objection to the above planning application, based on the information provided

WATER COMMENT

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,



This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to



Visit us online [www.thameswater.co.uk](http://www.thameswater.co.uk) , follow us on twitter [www.twitter.com/thameswater](https://www.twitter.com/thameswater) or find us on [www.facebook.com/thameswater](https://www.facebook.com/thameswater). We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.