


Bryan, Sylvia

From: BCTAdmin@thameswater.co.uk
Sent: 14 November 2006 16:35
To: Env DC Mail - PF
Subject: 3rd Party Planning Application - 2006/4978/C

London Borough of Camden
Camden Town Hall
Argyle Street
Euston Road
London
WC1H 8EQ

Our DTS Ref: 13271
Your Ref: 2006/4978/C

14 November 2006



Dear Sir/Madam

Re: 14A, REDINGTON ROAD, LONDON, NW3 7RG

Waste Comments

BASEMENT - Thames Water requests that the Applicant should incorporate within their proposal protection to the property by, for example, non-return valve or other suitable device to avoid the risk of backflow at a later date, on the assumption that the sewerage network may surcharge to ground level during storm conditions.

On the basis of information provided, Thames Water would advise that with regard to sewerage infrastructure we would not have any objection to the above planning application.

Water Comments

On the basis of information provided, Thames Water would advise that with regard to water infrastructure we would not have any objection to the above planning application.

Yours faithfully

Development Control Department

Thames Water
Development Control
Asset Investment Unit
Maple Lodge
Denham Way
Rickmansworth
Herts WD3 9SQ
Tel: 01923 898072

This is an automated email, please do not reply to the sender. If you wish to reply to this email click on the link below.

devcon.team@thameswater.co.uk

Prepare for cold weather by lagging all pipes and tanks in the loft space or anywhere else that may be liable to freezing.

For more winter wise tips, visit our website at www.thameswater.co.uk/waterwise.

RWE Thames Water plc, Registered Office Clearwater Court, Vastern Road, Reading, Berkshire, RG1 8DB. Registered No. 2366623. This e-mail is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of RWE Thames Water plc or its subsidiaries. If you are not the intended recipient of this e-mail you may not copy, use, forward or disclose its contents to any other person ; please notify our Computer Service Desk on +44 (0)118 9593587 and destroy and delete the message and attachments from your system.

For more information on Thames Water visit our web site at <http://www.thameswater.co.uk>