

Application ref: 2019/1298/P
Contact: Sofie Fieldsend
Tel: 020 7974 4607
Date: 1 May 2019

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

AGA Projects Ltd
77 St John's Road
Westcliff-on-Sea
SS0 7JY
United Kingdom

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
11-15 Emerald Street
London
WC1N 3QL

Proposal: Installation of 6x air con units at roof level.

Drawing Nos: 181109-LP; 181109-E-1; 181109-E-2; 181109-E-3; 181109-E-4; 181109-P-1; 181109-P-2; 181109-P-3; 181109-P-4 and Noise impact assessment ref. 7933-NIA-02-RevA by Clement Acoustics dated 6th March 2019.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans:

181109-LP; 181109-E-1; 181109-E-2; 181109-E-3; 181109-E-4; 181109-P-1;

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 Noise levels at a point 1 metre external to sensitive facades shall be at least 10dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 15dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 4 Machinery, plant or equipment and ducting at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Reasons for granting permission:

The proposal is for 6x air conditioning units at roof level which will sit alongside 3 existing units. The units will each measure 0.99m wide, have a depth of 0.32m and stand at 0.94m. The proposed units would not be visible from the street, given their small scale and siting on the roof and set back from the front and rear edges. Overall, given the small scale nature of the development and the fact that it would not be subject to public views, it is considered that the proposal would preserve the character and appearance of the host property, streetscene and the wider conservation area.

A noise survey has been submitted in support of the application. The Council's Environmental Health officer has reviewed the information and considers it to be acceptable, subject to noise compliance and the plant being mounted with proprietary anti-vibration isolators, both are secured by planning condition. The development would therefore not result in a material impact on the amenity of neighbouring properties in terms of noise. Furthermore, the development due to its scale, siting and design is not considered to cause harm to the amenity of the neighbouring properties in terms of loss of light, privacy or overlooking.

No comments were received during the consultation period. The planning history of the site has been taken into account when coming to this decision.

Special attention has been paid to the desirability of preserving or enhancing the character or appearance of the Conservation Area, under s.72 of the Planning (Listed Buildings and Conservation Area) Act 1990 as amended by the Enterprise and Regulatory Reform Act (ERR) 2013.

As such, the proposed development is in general accordance with policies G1, CC1, A1, A4, D1 and D2 of the London Borough of Camden Local Plan 2017. The proposed development also accords with the London Plan 2016 and the National Planning Policy Framework 2019.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 4 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 5 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and

Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned above the printed name and title.

Daniel Pope
Chief Planning Officer