

## LONDON BOROUGH OF CAMDEN

ACCESS COMMENTS

---

From: Philippa Jackson  
Tel. number: 020 7974 2305  
Ref: **2019/1573/P**  
Date: 27<sup>th</sup> May 2019

To: **Mark Chan**

---

**Re: 6-7 Bedford Row, London, WC1R 4BS**

The Proposed Work:

**Part removal of existing entrance steps for the installation of a new vertical rising stair/ platform lift to allow for ambulant disabled/ wheelchair access into the premises.**

The installation of a sesame lift is most welcome as it balances the historic nature of the building with the need to provide access. Please ensure that any fire strategy is updated to cover this access point.

The external call button should be operable with one clenched fist, should be at an accessible height and ideally should give an indication that the call has been answered that is clear to all including those with speech, visual and hearing difficulties.