



Radiators Schedule									
RAD REF	LOCATION	MANUFACTURER	MODEL	TYPE	HEIGHT (mm)	LENGTH (mm)	OUTPUT (W)	VALVES	NOTES
RG1	WC (G)	-	-	-	-	-	1195	-	Existing
RG2	WC (B)	-	-	-	-	-	1195	-	Existing
RG3	Circulation	-	-	-	-	-	956	-	Existing
RG4	Toilet (S/Dis)	-	-	-	-	-	956	-	Existing
RG5	Group Room	-	-	-	-	-	1195	-	Existing
RG6	WC (ASD)	Stelrad	Compact	K2	600	500	866	TRV/LSV	New

COPYRIGHT
This drawing is copyright and may not be altered, reproduced or used other than for the Contract Works for which it is issued without written permission.
© : Johns Slater and Haward Ltd.

Notes:

- This drawing should be read in conjunction with JSH mechanical services specification ref: EB/CR/5557/M.
- The School has advised that there is asbestos products in the working areas. The Contractor shall communicate with the Main Contractor and the School prior to any works being undertaken.

Legend:

- Pipework run in ceiling void (CV)
- Pipework run at high level (HL)
- Pipework run at low level (LL)
- Pipework run below ground level (UG)
- Pipework drop / rise
- Existing Pipework run in ceiling void (CV)
- Existing Pipework run at high level (HL)
- Existing Pipework run at low level (LL)
- Existing Pipework run below ground level (UG)
- Existing Pipework drop / rise
- Isolating valve (IV)
- Commissioning set (CS)
- Radiator

P01	Tender Issue	CR	EB	05/19
REV	DESCRIPTION	DR'WN	CHK'D	DATE

Johns Slater and Haward
Chartered Building Services Consultants
Ardennais House, 6 Sorrel Horse Mews, Grimwade St, Ipswich IP4 1LN
01473 255965, engineers@jshipswich.co.uk, www.jshipswich.co.uk



CLIENT:



PROJECT:

Primrose Hill Primary School ARP

DRG TITLE:

Ground Floor
Proposed Heating Layout
Sheet 1 of 2

SCALE: 1:50 @ A1	STATUS: D2 - Tender	PROJECT: 5557.00	ORIGINATOR: JSH
ZONE: XX	LEVEL: 00	TYPE: DR	DRG No. REV M-0201 P01

FOR CONTINUATION SEE DRAWING No. 5557-JSH-XX-ZZ-DR-M-0202