

**London office**

1B(c) Yukon Road  
London  
SW12 9PZ  
Tel: 0203 475 2280

**Manchester office**

105 Manchester Road  
Bury  
BL9 0TD  
Tel: 0161 850 2280

**8 EMERALD STREET,  
LONDON**

**NOISE IMPACT ASSESSMENT**

Report **14957-NIA-01**

Prepared on 12 June 2019

Issued For:

**AGA Projects Ltd**

**77 St John's Road**

**Westcliff-on Sea**

**Essex**

**SS0 7JY**



**Contents**

---

1.0 INTRODUCTION ..... 1

2.0 SITE DESCRIPTION ..... 1

3.0 ENVIRONMENTAL NOISE SURVEY ..... 1

3.1 Procedure ..... 1

3.2 Equipment ..... 2

4.0 RESULTS ..... 3

5.0 NOISE CRITERIA ..... 3

6.0 PLANT NOISE IMPACT ASSESSMENT ..... 4

6.1 Proposed Installation ..... 4

6.2 Noise Impact Assessment ..... 4

6.3 British Standard Requirements ..... 5

7.0 CONCLUSION ..... 6

**List of Attachments**

---

14957-SP1	Indicative Site Plan
14957-TH1	Environmental Noise Time History
Appendix A	Glossary of Acoustic Terminology
Appendix B	Acoustic Calculations

## 1.0 INTRODUCTION

---

Clement Acoustics has been commissioned by AGA Projects Ltd to measure existing background noise levels at 8 Emerald Street, London. Measured noise levels have been used to determine noise emissions criteria for a proposed plant installation in agreement with the planning requirements of the London Borough of Camden.

This report presents the results of the environmental survey followed by noise impact calculations and outlines any necessary mitigation measures.

## 2.0 SITE DESCRIPTION

---

Current proposals are to install 1 No. Daikin RXYSCQ5TV1 condenser unit on the 4<sup>th</sup> storey roof of the building.

It is understood that the proposed plant unit will be for commercial use, operational during the hours 08:00 - 18:00.

The closest receiver has been identified as the 4<sup>th</sup> storey window on the front façade of the building. This nearest noise sensitive receiver was identified through observations on-site. If there are any receivers closer to that identified within this report then a further assessment will need to be carried out. Therefore, the closest noise sensitive receptor should be confirmed by the client before the plant is installed or any noise mitigation measures are implemented.

Locations are shown in attached site plan 14957-SP1.

## 3.0 ENVIRONMENTAL NOISE SURVEY

---

### 3.1 Procedure

Measurements were undertaken at one position as shown on indicative site drawing 14957-SP1. The choice of this position was based both on accessibility and on collecting representative noise data in relation to the site.

The microphone was mounted on a 4<sup>th</sup> storey balcony at the front of the building. The microphone was positioned 1 m in front of the wall and as such the monitoring position is not considered free-

field according to the guidance of BS 4142: 2014. Based on the presence of the reflective surface and the nature of surrounding noise sources, a correction for reflections of 3 dB has been applied, in line with the recommendations of the standard. Noise levels at the monitoring position were dominated by traffic noise during the installation and collection of equipment.

Continuous automated monitoring was undertaken for the duration of the survey between 12:05 on 06 June 2019 and 11:40 on 07 June 2019.

Weather conditions were generally dry with light winds, therefore suitable for the measurement of environmental noise.

The measurement procedure generally complied with BS 7445: 1991: *'Description and measurement of environmental noise, Part 2- Acquisition of data pertinent to land use'*.

### 3.2 Equipment

The equipment calibration was verified before and after use and no abnormalities were observed.

The equipment used was as follows.

- 1 No. Svantek Type 977 Class 1 Sound Level Meter
- Norsonic Type 1251 Class 1 Calibrator

## 4.0 RESULTS

The  $L_{Aeq: 5min}$ ,  $L_{Amax: 5min}$ ,  $L_{A10: 5min}$  and  $L_{A90: 5min}$  acoustic parameters were measured at the location shown in site drawing 14957-SP1.

Measured noise levels are shown as a time history in Figure 14957-TH1, with average ambient and minimum background noise levels summarised in Table 4.1.

	Average ambient noise level	Minimum background noise level
	$L_{eq: T}$	$L_{90: 5min}$
Daytime (07:00 - 23:00)	62 dB(A)	52 dB(A)
Night-time (23:00 - 07:00)	59 dB(A)	49 dB(A)
Proposed Operating Hours (08:00 - 18:00)	61 dB(A)	53 dB(A)

**Table 4.1: Average ambient and minimum background noise levels**

## 5.0 NOISE CRITERIA

The London Borough of Camden general criteria for noise emissions for industrial and commercial noise sources are as follows:

*“A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 ‘Methods for rating and assessing industrial and commercial sound’ (BS 4142) will be used. For such cases a ‘Rating Level’ of 10 dB below background (15dB if tonal components are present) should be considered as the design criterion).”*

It is understood that the proposed plant unit will be for commercial use, operational during the hours 08:00 - 18:00. As tonal components would not be expected, which has been confirmed through manufacturer stated spectral noise emissions, the noise emissions criterion of 43 dB(A), the value 10 dB below the minimum measured background noise level during the proposed operating hours, will be used for the purpose of this assessment.

## 6.0 PLANT NOISE IMPACT ASSESSMENT

### 6.1 Proposed Installation

The proposed plant installation comprises the following:

- 1 No. Daikin RXYSCQ5TV1 condenser unit

Noise emissions for the proposed plant units, as provided by the manufacturer, are shown in Table 6.1. Loudest modes of operation have been used in order to present a robust worst case assessment.

Unit	Sound Pressure Levels (at 1 meter, dB) in each Frequency Band								dB(A)
	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	
Daikin RXYSCQ5TV1	51	53	52	53	47	41	34	27	52

**Table 6.1: Manufacturer provided noise emissions levels**

The proposed plant location is on the 4<sup>th</sup> storey roof of the building which is shown on indicative site plan 14957-SP1.

The closest receiver has been identified as the 4<sup>th</sup> storey window on the front façade of the building which is a minimum of 5 m from the proposed plant location, with line of sight screening provided by the building fabric.

### 6.2 Noise Impact Assessment

Taking into account all necessary acoustic corrections, the resulting noise level at the identified residential windows would be as shown in Table 6.2. Detailed calculations are shown in Appendix B.

Receiver	Operating Hours Criterion	Noise Level at Receiver (due to proposed plant)
Nearest Residential Property	43 dB(A)	39 dB(A)

**Table 6.2: Noise levels and criterion at noise sensitive receivers**

As presented in Table 6.2 and Appendix B, the proposed plant installation would be expected to meet the requirements of the proposed criteria.

### 6.3 British Standard Requirements

Further calculations have been undertaken to assess whether the noise emissions from the proposed plant unit would be expected to meet recognised British Standard recommendations, in order to further ensure the amenity of nearby noise sensitive receivers.

British Standard 8233: 2014 '*Guidance on sound insulation and noise reduction for buildings*' gives recommendations for acceptable internal noise levels in residential properties. Assuming worst case conditions, of the closest window being for a bedroom, BS 8233: 2014 recommends 35 dB(A) as being acceptable internal resting conditions during daytime.

With loudest external levels of 39 dB(A), acceptable internal conditions would be met by taking the attenuation of the window itself into consideration. According to BS 8233: 2014, a typical building façade with a partially open window offers 15 dB attenuation.

It can therefore be predicted that, in addition to meeting the requirements of the set criteria, the emissions from the proposed plant would be expected to meet the most stringent recommendations of the relevant British Standard, with neighbouring windows partially open. Predicted levels are shown in Table 6.3.

Receiver	Recommended Target – <i>For resting/sleeping conditions in a bedroom, in BS 8233: 2014</i>	Noise Level at Receiver (due to plant installation)
Inside Residential Window	35 dB(A)	24 dB(A)

**Table 6.3: Noise levels and criteria inside nearest residential space**

## 7.0 CONCLUSION

---

An environmental noise survey has been undertaken at 8 Emerald Street, London. The results of the survey have enabled criteria to be set for noise emissions from the proposed plant units in accordance with the requirements of the London Borough of Camden.

A noise impact assessment has then been undertaken using manufacturer noise data to predict the noise levels, due to the proposed plant, at the nearby noise sensitive receivers.

Calculations show that noise emissions from the proposed plant units should meet the requirements of the London Borough of Camden.

Report by

**Kenny Macleod AMIOA**

Checked by


**Duncan Martin MIOA**





- Noise Survey Position
- Noise Sensitive Receiver

**8 Emerald Street, London**  
Environmental Noise Time History  
06 June 2019 to 17 June 2019



## GLOSSARY OF ACOUSTIC TERMINOLOGY

### **dB(A)**

The human ear is less sensitive to low (below 125Hz) and high (above 16kHz) frequency sounds. A sound level meter duplicates the ear's variable sensitivity to sound of different frequencies. This is achieved by building a filter into the instrument with a similar frequency response to that of the ear. This is called an A-weighting filter. Measurements of sound made with this filter are called A-weighted sound level measurements and the unit is dB(A).

### **L<sub>eq</sub>**

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level L<sub>eq</sub>. The L<sub>eq</sub> is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

### **L<sub>10</sub>**

This is the level exceeded for not more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise

### **L<sub>90</sub>**

This is the level exceeded for not more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

### **L<sub>max</sub>**

This is the maximum sound pressure level that has been measured over a period.

### **Octave Bands**

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 10 such octave bands whose centre frequencies are defined in accordance with international standards.

### **Addition of noise from several sources**

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than one alone and 10 sources produce a 10dB higher sound level.

### Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

### Subjective impression of noise

Sound intensity is not perceived directly at the ear; rather it is transferred by the complex hearing mechanism to the brain where acoustic sensations can be interpreted as loudness. This makes hearing perception highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a reasonable guide to help explain increases or decreases in sound levels for many acoustic scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud
20	About 4 times as loud

### Barriers

Outdoor barriers can be used to reduce environmental noises, such as traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and its construction.

### Reverberation control

When sound falls on the surfaces of a room, part of its energy is absorbed and part is reflected back into the room. The amount of reflected sound defines the reverberation of a room, a characteristic that is critical for spaces of different uses as it can affect the quality of audio signals such as speech or music. Excess reverberation in a room can be controlled by the effective use of sound-absorbing treatment on the surfaces, such as fibrous ceiling boards, curtains and carpets.

## APPENDIX B

### 14957 8 EMERALD STREET, LONDON

#### EXTERNAL PLANT NOISE EMISSIONS CALCULATION

**Receiver: Nearest Residential Receiver**

Source: Proposed plant installation

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
<b>Manufacturer provided sound pressure level at 1 metre</b>									
Daikin RXYSCQ5TV1	51	53	52	53	47	41	34	27	52
Correction for reflections, dB	6	6	6	6	6	6	6	6	
Attenuation provided by line of sight screening, dB	-5	-5	-5	-5	-5	-5	-5	-5	
Distance correction to receiver, dB (5 m)	-14	-14	-14	-14	-14	-14	-14	-14	
<b>Sound pressure level at receiver</b>	<b>38</b>	<b>40</b>	<b>39</b>	<b>40</b>	<b>34</b>	<b>28</b>	<b>21</b>	<b>14</b>	<b>39</b>

<b>Design Criterion</b>	<b>43</b>
-------------------------	-----------

#### BS 8233 ASSESSMENT CALCULATION

**Receiver: Inside Nearest Residential Window**

Source: Proposed plant installation

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Sound pressure level outside window	38	40	39	40	34	28	21	14	39
Minimum attenuation from partially open window, dB	-15	-15	-15	-15	-15	-15	-15	-15	
<b>Sound pressure level inside nearest noise sensitive premises</b>	<b>23</b>	<b>25</b>	<b>24</b>	<b>25</b>	<b>19</b>	<b>13</b>	<b>6</b>	<b>0</b>	<b>24</b>

<b>Design Criterion</b>	<b>35</b>
-------------------------	-----------