

Application ref: 2018/1209/P
Contact: Kristina Smith
Tel: 020 7974 4986
Date: 17 June 2019

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Rolfe Judd Planning
Old Church Court
Claylands Road
Oval
London
SW8 1NZ

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:

The Good Mixer
28-30 Inverness Street
LONDON
NW1 7HJ

Proposal:

Erection of single storey roof extension and two storey rear and front infill extensions plus various external alterations in association with the refurbishment of public house (Class A4) and change of use of upper floors and part of lower floors from ancillary functions of public house (Class A4) to office (Class B1)

Drawing Nos: 0500; 0501; 0999; 1000; 1001; 1002; 1003; 1100; 1101; 1102; 1103; 1200; 1201; 1998B; 1999B; 2000C; 2001B; 2002B; 2003B; 2004C; 2100C; 2101B; 2102B; 2103B; 2200B; 2201C; 2300; Planning Brochure Revision D (Dated December 2018); Daylight and Sunlight assessment (prepared by Point 2 Surveyors, dated July 2018); Planning statement (dated 1 March 2018)

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and

Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: 0500; 0501; 0999; 1000; 1001; 1002; 1003; 1100; 1101; 1102; 1103; 1200; 1201; 1998B; 1999B; 2000C; 2001B; 2002B; 2003B; 2004C; 2100C; 2101B; 2102B; 2103B; 2200B; 2201C; 2300; Planning Brochure Revision D (Dated December 2018); Daylight and Sunlight assessment (prepared by Point 2 Surveyors, dated July 2018); Planning statement (dated 1 March 2018)

Reason:

For the avoidance of doubt and in the interest of proper planning.

- 4 Before the development commences, details of secure and covered cycle storage area for 4 cycles associated with the office floorspace (as shown on drawing no. 1999A) shall be submitted to and approved by the local planning authority. The approved facility shall thereafter be provided in its entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017.

- 5 Prior to commencement of any works to the rooftop plant area, full details of:

- a. the proposed plant equipment including manufacturers specifications
- b. an accompanying acoustic report demonstrating how the requirements of condition 6 will be met by the associated plant and any necessary acoustic mitigation and
- c. details of the associated screening, including materials

shall be submitted to and approved by the Local Planning Authority in writing. All mitigation measures shall be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1, A4 and D1 of the London Borough of Camden Local Plan 2017.

- 6 The total noise from fixed plant associated with the application site, when at a point 1m external to the nearest noise sensitive residential facades shall be at least 10 dB(A) less than the existing background measurement (LA90),

expressed in dB(A), when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that is distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses(bangs, clicks, clatters, thumps), then the noise levels from the plant/equipment at any sensitive façade shall be at least 15 dB(A) below background noise level.

Reason: To safeguard the amenities of neighbouring noise sensitive receptors in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 7 Before the relevant part of the work is begun, detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority:

a) Details including sections at 1:10 of all windows, balustrades and doors

b) Manufacturer's specification details of the brickwork to be submitted and a sample to be provided on site.

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 8 Prior to completion of the third storey extension, details of the sound insulation of the floor/ ceiling/ walls separating the public house use from the office above shall be submitted to and approved in writing by the local planning authority. Such details shall demonstrate that the sound insulation value $D_{nT,w}$ and $L'_{nT,w}$ is enhanced by at least 10dB above the Building Regulations value and include such mitigation measures as necessary in order to achieve the 'Good' criteria of BS8233:2014.

The details as approved shall be implemented prior to first occupation of the offices and thereafter be permanently retained.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the

Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

- 3 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned above the printed name and title of the Chief Planning Officer.

Daniel Pope
Chief Planning Officer