



Application ref: 2018/5338/P
Contact: Elaine Quigley
Tel: 020 7974 5101
Date: 3 July 2019

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Genesis Architects Ltd
7 St Margarets Road
Stanstead Abbots Ware
SG12 8EP

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:
8 Agamemnon Road
London
NW6 1DY

Proposal:

Change of use from 6 x studio flats (Class C3) and 2 x bedsits (Class C4) to 4 x 2-bed flats (Class C3); extension of existing basement, including new front and rear lightwells; excavation of existing basement to lower floor by 1.0m; erection of single storey rear extension at ground floor level; erection of rear cycle stores and front boundary wall. Drawing Nos: GAL 277 (PC) 001; 002 rev A; 003 rev C; 004 rev B; Basement Impact Assessment Report produced by Chelmer Global Ltd dated October 2018; Geo-environmental Interpretive Report November 2018; Addendum 1 to BIA produced by Chelmer Global Ltd dated 28th March 2019; Adopted Services Information produced by Chelmer Global Ltd dated March 2019; Construction Management Plan produced by David Joseph Consulting dated January 2019.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and

Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017 and Policy 2 of the Fortune Green and West Hampstead Neighbourhood Plan (2015).

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans GAL 277 (PC) 001; 002 rev A; 003 rev C; 004 rev B; Basement Impact Assessment Report produced by Chelmer Global Ltd dated October 2018; Geo-environmental Interpretive Report November 2018; Addendum 1 to BIA produced by Chelmer Global Ltd dated 28th March 2019; Adopted Services Information produced by Chelmer Global Ltd dated March 2019; Construction Management Plan produced by David Joseph Consulting dated January 2019.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 Before the relevant part of the work is begun, detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority:

- a) Details including sections at 1:10 of all windows (including jambs, head and cill), ventilation grills, external doors and gates;

- b) Plan, elevation and section drawings at 1:50 of the front boundary wall

- c) Plan, elevation and section drawings at 1:10 of the front lightwell

- c) Manufacturer's specification details of all facing materials (to be submitted to the Local Planning Authority) and samples of those materials (to be provided on site).

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017 and Policy 2 of the Fortune Green and West Hampstead Neighbourhood Plan (2015).

- 5 Prior to commencement of development details of a sustainable urban drainage system shall be submitted to and approved in writing by the local planning authority. The system shall be implemented as part of the development and thereafter retained and maintained.

Reason: To reduce the rate of surface water run-off from the buildings and limit the impact on the storm-water drainage system in accordance with Policies CC1, CC2, CC3 of the London Borough of Camden Local Plan 2017.

- 6 The development hereby approved shall achieve a maximum internal water use of 110litres/person/day. The dwelling/s shall not be occupied until the Building Regulation optional requirement has been complied with.

Reason: To ensure the development contributes to minimising the need for further water infrastructure in an area of water stress in accordance with Policies CC1, CC2, CC3 of the London Borough of Camden Local Plan 2017.

- 7 Before the development commences, details of secure and covered cycle storage area for 8 cycles shall be submitted to and approved by the local planning authority. The approved facility shall thereafter be provided in its entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017 and Policy 7 of the Fortune Green and West Hampstead Neighbourhood Plan (2015).

- 8 The development hereby approved shall not commence until such time as a suitably qualified chartered engineer with membership of the appropriate professional body has been appointed to inspect, approve and monitor the critical elements of both permanent and temporary basement construction works throughout their duration to ensure compliance with the design which has been checked and approved by a building control body. Details of the appointment and the appointee's responsibilities shall be submitted to and approved in writing by the local planning authority prior to the commencement of development. Any subsequent change or reappointment shall be confirmed forthwith for the duration of the construction works.

Reason: To safeguard the appearance and structural stability of neighbouring buildings and the character of the immediate area in accordance with the requirements of policies D1 and A5 of the London Borough of Camden Local Plan 2017.

- 9 The roof of the ground floor rear extension hereby approved shall not be used as a roof terrace and shall only be accessed for maintenance purposes.

Reason: In order to prevent unreasonable overlooking of neighbouring premises in accordance with the requirements of policies A1 and D1 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound

insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).

- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 4 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 5 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.
- 6 You are reminded that this decision only grants permission for permanent residential accommodation (Class C3). Any alternative use of the residential units for temporary accommodation, i.e. for periods of less than 90 days for

tourist or short term lets etc, would constitute a material change of use and would require a further grant of planning permission.

- 7 You are reminded of the need to provide adequate space for internal and external storage for waste and recyclables. For further information contact Council's Environment Services (Waste) on 020 7974 6914/5 or see the website <http://www.camden.gov.uk/ccm/content/environment/waste-and-recycling/twocolumn/new-recycling-rubbish-and-reuse-guide.en>.
- 8 Your proposals may be subject to control under the Party Wall etc Act 1996 which covers party wall matters, boundary walls and excavations near neighbouring buildings. You are advised to consult a suitably qualified and experienced Building Engineer.
- 9 If a revision to the postal address becomes necessary as a result of this development, application under Part 2 of the London Building Acts (Amendment) Act 1939 should be made to the Camden Contact Centre on Tel: 020 7974 4444 or Environment Department (Street Naming & Numbering) Camden Town Hall, Argyle Street, WC1H 8EQ.
- 10 Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:
<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



Daniel Pope
Chief Planning Officer

