



Application ref: 2018/4230/P
Contact: David Peres Da Costa
Tel: 020 7974 5262
Date: 8 March 2019

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

DP9 Ltd
100 Pall Mall
LONDON
SW1Y 5NQ

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:
St Matthews Lodge
50 Oakley Square
London
NW1 1NB

Proposal:

Erection of single storey roof extension at 5th floor level to provide 5 flats (3 x 2-bed and 2 x 1-bed) with roof terraces facing Crowndale Road and Oakley Square (Class C3), including erection of cycle store and alteration to waste store.

Drawing Nos: Existing drawings: 2106-PL-: 100; 102; 103; 105; 106; 107; 108;

Proposed drawings: 2106-PL-: 112 Rev B; 113 Rev D; 114 Rev B; 115; 116; 117; 118; 120;

Supporting documents: Air Quality Assessment prepared by Eden Green Environmental dated 05/12/2018; Energy And Sustainability Statement prepared by EAL Consult dated January 2019; Heritage Statement prepared by KM Heritage; Planning Statement prepared by DP9 dated September 2018; Design and Access Statement prepared by Echlin dated August 2018; Sunlight and Daylight Study prepared by Echlin dated November 2018

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans:

Existing drawings: 2106-PL-: 100; 102; 103; 105; 106; 107; 108;

Proposed drawings: 2106-PL-: 112 Rev B; 113 Rev D; 114 Rev B; 115; 116; 117; 118; 120;

Supporting documents: Air Quality Assessment prepared by Eden Green Environmental dated 05/12/2018; Energy And Sustainability Statement prepared by EAL Consult dated January 2019; Heritage Statement prepared by KM Heritage; Planning Statement prepared by DP9 dated September 2018; Design and Access Statement prepared by Echlin dated August 2018; Sunlight and Daylight Study prepared by Echlin dated November 2018

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 Prior to the commencement of any works on site, details demonstrating how trees to be retained shall be protected during construction work shall be submitted to and approved by the local planning authority in writing. Such details shall follow guidelines and standards set out in BS5837:2012 "Trees in Relation to Construction". All trees on the site, or parts of trees growing from adjoining sites, unless shown on the permitted drawings as being removed, shall be retained and protected from damage in accordance with the approved protection details.

Reason: To ensure that the development will not have an adverse effect on existing trees and in order to maintain the character and amenity of the area in accordance with the requirements of policies A2 and A3 of the London Borough of Camden Local Plan 2017.

- 4 Air quality monitoring shall be implemented on site. No development shall take place until:
 - a. prior to installing monitors, full details of the air quality monitors have been submitted to and approved by the local planning authority in writing. Such details shall include the location, number and specification of the monitors, including evidence of the fact that they have been installed in line with guidance outlined in the GLA's Control of Dust and Emissions during Construction and Demolition Supplementary Planning Guidance;
 - b. prior to commencement, evidence has been submitted demonstrating that the monitors have been in place for at least 3 months prior to the proposed implementation date.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and CC4 of the London Borough of Camden Local Plan 2017.

- 5 Before the relevant part of the work is begun, detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority:

a) Details including sections at 1:10 of all windows

b) Detailed drawings at 1:10 (including sections) and materials of all balconies and roof terrace balustrades.

c) Manufacturer's specification details of all facing materials (to include those for roof extension and bin/cycle store) (to be submitted to the Local Planning Authority) and samples of those materials (to be provided on site).

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 6 Before the brickwork is commenced, a sample panel of the facing brickwork demonstrating the proposed colour, texture, face-bond and pointing shall be provided on site and approved in writing by the local planning authority. The development shall be carried out in accordance with the approval given. The approved panel shall be retained on site until the work has been completed.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy D1 of the London Borough of Camden Local Plan 2017.

- 7 The secure and covered cycle storage area for 9 (long stay) cycles and the secure cycle store for 2 (short stay) cycles shall be provided in its entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017.

- 8 Noise levels at a point 1 metre external to sensitive facades shall be at least 10dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece

of plant/equipment at any sensitive façade shall be at least 15dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 9 Prior to the installation of the air source heat pumps (ASHPs), full details of the ASHPs including manufacturer's specifications, noise levels, attenuation, anti-vibration measures and an acoustic report (demonstrating that the ASHPs would comply with the Noise and vibration thresholds in Appendix 3 of the Camden Local Plan), shall be submitted to and approved by the Local Planning Authority in writing. The ASHPs shall not proceed other than in complete accordance with such scheme as has been approved. All such measures shall be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

10 Solar PV

Prior to first occupation of the flats hereby approved, drawings and data sheets showing the location, extent and predicted energy generation of photovoltaic cells and associated equipment to be installed on the building shall have been submitted to and approved by the Local Planning Authority in writing. The measures shall include the installation of a meter to monitor the energy output from the approved renewable energy systems. A site-specific lifetime maintenance schedule for each system, including safe roof access arrangements, shall be provided. The cells shall be installed in full accordance with the details approved by the Local Planning Authority and permanently retained and maintained thereafter.

Reason: To ensure the development provides adequate on-site renewable energy facilities in accordance with the requirements of policy CC1 of the London Borough of Camden Local plan Policies

11 Internal Noise Levels

The flats hereby approved adjacent to lifts shall be designed in accordance with BS 8233:2014 to attain the following internal noise levels:

Room Max noise level (dB LAmax, F)

Bedroom 25
Living room 30
Other areas 35

Prior to commencement of the use hereby permitted, evidence demonstrating the required internal noise levels shall be submitted to and approved in writing by the local planning authority.

Reason: To safeguard the amenities of the future occupiers in accordance with the requirements of policies D1, A1, and A4 of the London Borough of Camden Local Plan 2017.

- 12 Prior to commencement of development, full details in respect of the brown roof in the area indicated on the approved roof plan shall be submitted to and approved by the local planning authority. The details shall include
- i. a detailed scheme of maintenance
 - ii. sections at a scale of 1:20 with manufacturers details demonstrating the construction and materials used and showing a variation of substrate depth with peaks and troughs
 - iii. full details of planting species and density

The living roofs shall be fully provided in accordance with the approved details prior to first occupation and thereafter retained and maintained in accordance with the approved scheme.

Reason: In order to ensure the development undertakes reasonable measures to take account of biodiversity and the water environment in accordance with policies CC1, CC2, CC3, D1 and A3 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 This proposal may be liable for the Mayor of London's Community Infrastructure Levy (CIL) and the Camden CIL. Both CILs are collected by Camden Council after a liable scheme has started, and could be subject to surcharges for failure to assume liability or submit a commencement notice PRIOR to commencement. We issue formal CIL liability notices setting out how much you may have to pay once a liable party has been established. CIL payments will be subject to indexation in line with construction costs index. You can visit our planning website at www.camden.gov.uk/cil for more information, including guidance on your liability, charges, how to pay and who to contact for

more advice.


- 4 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.
- 5 You are advised that Section 44 of the Deregulation Act 2015 [which amended the Greater London Council (General Powers) Act 1973]] only permits short term letting of residential premises in London for up to 90 days per calendar year. The person who provides the accommodation must be liable for council tax in respect of the premises, ensuring that the relaxation applies to residential, and not commercial, premises.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



David Joyce
Director of Regeneration and Planning