



**NOTE:**

- ALL JOINTS BETWEEN PLASTERBOARD LAYERS TO BE STAGGERED;
- SEAL ALL JOINTS WITH TAPE OR CAULK WITH SEALANT;
- ENSURE NO RIGID CONNECTIONS WHERE RESILIENT HANGERS/BARS/BATTENS ARE PROPOSED.
- ANY EXPOSED STEELWORK/SERVICES/BEAMS PASSING THROUGH A SEPARATING PARTITION/CEILING MUST BE BOXED-IN WITH 2NO. 15MM SOUNDBLOC LAYERS WITH A 50MM CAVITY LOOSELY FILLED WITH MINERAL WOOL.
- MINERAL WOOL SHOULD BE LOOSELY LAID THROUGHOUT ALL CAVITIES. MINERAL WOOL MUST NOT BE TIGHTLY PACKED;
- PENETRATIONS THROUGH THE CEILING LEAVES MUST BE AVOIDED. WHERE UNAVOIDABLE, PENETRATIONS MUST BE MADE AS SMALL AS POSSIBLE AND FULLY SEALED TO THE DEPTH OF THE PLASTERBOARD WITH NON-SETTING MASTIC. IF LARGER PENETRATIONS ARE FORMED THESE SHOULD BE SUITABLY PATTTRESSED.

Project: TE - 43-47 Shelton Street, London

Title: Proposed Layout of Plant Room

Client: Space Engineering Ltd

Drawing No: RF87962 SK001F

Drawn By: LC    Check By: LQ    Date: 07/09/2018

Scale: N/A    Projection:

Date:	Rev:	Description:
16/01/19	F	Re-Issued For Approval (LC)
15/01/19	E	Issued For Approval (LC)
30/11/18	D	Attenuation Sizes Confirmed (LC)
09/11/18	C	Re-Issued For Approval (LC)
19/09/18	B	Issued For Approval (LC)
07/09/18	A	Issued For Discussion (LC)

**Notes:**

All dimensions in millimetres.  
 All external faces to be painted to a standard RAL colour (TBC by others).  
 All other faces galvanised.  
 All plant, ductwork & pipework to be fitted with suitable anti-vibration mounts & flexible connections.

**NSLO**  
Noise Solutions Ltd

Unit 6  
 LDL Business Centre  
 Station Road West  
 Ash Vale  
 GU12 5RT  
 Tel. 01252-519881  
 www.noisesolutions.co.uk

This drawing is the sole property of Noise Solutions Ltd. It must not be copied or lent without their prior knowledge and consent.