



PROPOSED ENCLOSURE DETAIL

IF IN DOUBT ASK
DO NOT SCALE. REPORT ALL DISCREPANCIES NO MATTER HOW SMALL.

TOLERANCES UNLESS OTHERWISE STATED:
GENERAL FABRICATIONS:-
 UP TO 300 + OR - (1.0mm) - 301 TO 1500 + OR - (2.0mm) - 1501 TO 3000 + OR - (3.0mm) - 3001 TO 6000 + OR - (4.0mm) - 6001 AND ABOVE (5.0mm MAXIMUM).
FRAMEWORK:-
 UP TO 300 + OR - (1.0mm) - 301 TO 1500 + (2.0m) OR - (1.0mm) - 1501 TO 3000 + (3.0mm) OR - (1.0mm) - 3001 TO 6000 + (4.0mm) OR - (1.0mm) - 6001 AND ABOVE + (5.0mm) OR - (1.0mm).
PANELS:-
 UP TO 300 + OR - (1.0mm) - 301 TO 1500 + (1.0m) OR - (2.0mm) - 1501 TO 3000 + (1.0mm) OR - (3.0mm) - 3001 TO 6000 + (1.0mm) OR - (4.0mm) - 6001 AND ABOVE + (1.0mm) OR - (5.0mm).

REMOVE ALL BURRS AND SHARP EDGES.

NOTES:
 • ENCLOSURE TO BE FLAT PACK CONSTRUCTION.
 • DISTRIBUTION FROM THE POINT OF OFFLOAD TO THE INSTALLATION AREA IS BY OTHERS.
 • ANY SCAFFOLDING / SAFE ACCESS / EDGE PROTECTION REQUIRED TO COMPLETE INSTALLATION IS TO BE PROVIDED BY OTHERS.
 • ALL DIMENSIONS ARE SUBJECT TO CHANGE FOLLOWING DETAILED SITE SURVEY TO BE COMPLETED WHEN BUILDERS WORK & CLADDING DETAIL IS COMPLETE.

MATERIALS:-
 FRAMEWORK - S235JR MILD STEEL SECTION
 END CAPS - BLACK MILD STEEL
 BASEPLATES/TABS - BLACK MILD STEEL
 TRIMS - Z275 PRE-GALV SHEET
 PANELS - Z275 PRE-GALVANISED MILD STEEL C/W MINERAL WOOL INFILL TISSUE WRAPPED, & Z275 PRE-GALVANISED PERFORATED COVER
 LOUVRES - Z275 PRE-GALVANISED MILD STEEL C/W MINERAL WOOL INFILL TISSUE WRAPPED, & Z275 PRE-GALVANISED PERFORATED COVER
 PAD ATTS - Z275 PRE-GALVANISED MILD STEEL C/W MINERAL WOOL INFILL GLASS TISSUE WRAPPED, & Z275 PRE-GALVANISED PERFORATED COVER

THE FOLLOWING ITEMS TO BE SUPPLIED UNTREATED AS PURCHASED:-
 DOOR HANDLES - PRESSED STEEL PRE-GALV FINISH
 HINGES - STAINLESS STEEL
 FIXINGS - ALL GRADE 8.8 ZINC PLATED

FINISH:-
 FRAMEWORK: - PPC FINISH, STANDARD RAL COLOUR TBC
 PANELS: - PRE-GALV NATURAL SELF FINISH (UNPAINTED)
 LOUVRE PANELS: - PPC FINISH, STANDARD RAL COLOUR TBC

QUANTITY:- - 1 ENCLOSURE REQUIRED
APPROXIMATE WEIGHT:- - 2215KGS

01	ISSUED FOR COMMENT	D.M	24/07/19
REV:	DESCRIPTION:	BY:	DATE:

AMENDMENTS:

Wakefield Acoustics Ltd
 FLUSH MILLS
 WESTGATE
 HECKMONDWIK
 WEST YORKSHIRE
 WF16 0EN
 TEL: +44 (0) 1924 418940 - FAX: +44 (0) 1924 418950
 web site: www.wakefieldacoustics.co.uk
 e-mail: noise@wakefieldacoustics.co.uk

INDUSTRIAL NOISE CONTROL TECHNOLOGY

TITLE: GENERAL ARRANGEMENT OF ACOUSTIC ENCLOSURE (COMMERCIAL 1)	DRAWN: D.M	DATE: 24/07/19
REF: PROMA, OLD DAIRY LONDON	CHECKED: A.O	DATE: 24/07/19
DRAWING No: C28336-101-01	REV: 01	SCALE: SHT-No
		NTS 1 of 1

THIS DRAWING IS THE COPYRIGHT OF WAKEFIELD ACOUSTICS LIMITED. IT MUST NOT BE COPIED OR DISCLOSED TO A THIRD PARTY WITHOUT WRITTEN CONSENT AND IS SUBJECT TO RECALL AT ANY TIME.

© 2018

SIZE:
A1