

Application ref: 2018/4345/P
Contact: Thomas Sild
Tel: 020 7974 3686
Date: 25 July 2019

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Gabor Gallov Architect
25 Goodge Place
London
W1T 4SP

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
25 Coptic Street and 40 New Oxford Street
London
WC1A 1NT

Proposal: Replacement of existing 700mm extract duct with 2 x 500mm ducts including anti-vibration brackets and supports to rear.

Drawing Nos: L01, L02, E 01, EP01, EE01, P01, PR25, PR-40, Risk Assessment for Odour - Fan Rescue Ltd (04/02/2019), Noise Impact Assessment 0423.NIAVA2725.19 - Venta Acoustics (23/04/2019).

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans and documents: L01, L02, E 01, EP01, EE01, P01,

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 and D2 of the London Borough of Camden Local Plan 2017.

- 4 The external noise level emitted from plant, machinery or equipment at the development with suggested mitigation measures hereby approved shall be lower than the lowest existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 5 Prior to use, machinery, plant or equipment and ducting at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 6 The approved ducts and associated extract fans shall not operate outside the hours of 8am to 11pm Monday-Sunday.

Reason: To safeguard the amenities of the surrounding premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Reasons for granting permission

The proposed 2 x 500mm ducts would replace an existing 700mm in the same siting to the rear of the building, and would be to the same height above roof level as now. The duct would not be visible to the street and the overall visual impact would not be significantly different than the existing situation. As such the proposals are considered to preserve the character of the surrounding Bloomsbury Conservation Area.

An odour assessment has been reviewed by the Council's Environmental Health Officer and found to be acceptable. A noise assessment has been reviewed and is acceptable subject to the inclusion of planning conditions requiring the installation of noise and vibration mitigation measures and restricting the noise output to within specified levels. A further condition would limit the hours of operation of the ducts and associated extractors to within 8am-11pm Monday-Sunday. As such the development would not result in unacceptable harm to neighbour amenity.

No objections were received prior to making this decision. The planning history of the site and surrounding area were taken into account. Special regard has been attached to the desirability of preserving or enhancing the conservation area, under s.72 of the Planning (Listed Buildings and Conservation Areas) Act 1990 as amended by the Enterprise and Regulatory Reform Act 2013.

The proposal is in general accordance with policies A1, A4, D1 and D2 of the Camden Local Plan 2017. The proposed development also accords with the policies of the London Plan 2016 and National Planning Policy Framework 2019.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 4 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website at <https://beta.camden.gov.uk/documents/20142/1269042/Camden+Minimum+Requirements+%281%29.pdf/bb2cd0a2-88b1-aa6d-61f9-525ca0f71319> or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these

hours.

- 5 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team London Borough of Camden 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) . Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is written over a light grey rectangular background.

Daniel Pope
Chief Planning Officer