
From: [REDACTED]
Sent: 30 July 2019 10:55
To: Planning
Subject: 3rd Party Planning Application - 2019/2915/P- New documents July 19

London Borough of Camden Our DTS Ref: 50989
Camden Town Hall Your Ref: 2019/2915/P- New documents July 19
Argyle Street
Euston Road
London
WC1H 8EQ

30 July 2019

Dear Sir/Madam

Re: 52, HOLMES ROAD, LONDON, NW5 3AB

Waste Comments

Thank you for consulting Thames Water for the discharge of matters relating to PILING. Thames Water are unable to support the discharge of this condition for the reasons outlined below.

Water Comments

Supplementary Comments

Within the report (Revised Basement Impact Assessment) there is a number of references to piling (page 14, 27 and 157). Can you please provide foundation construction method statement and drawings to demonstrate the construction sequence?

From Google Maps it can be seen that excavation and possible piling works have been undertaken without the condition being discharged. Therefore, there is a breach in the condition.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ

[REDACTED]

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk
Visit us online www.thameswater.co.uk, follow us on twitter www.twitter.com/thameswater or find us on www.facebook.com/thameswater. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.