

## Project name

**02 Be Lean - IMRI Wing (L2B)**

As designed

Date: Fri Jan 25 14:34:51 2019

## Administrative information

## Building Details

Address: LONDON,

## Certification tool

Calculation engine: SBEM

Calculation engine version: v5.4.b.0

Interface to calculation engine: DesignBuilder SBEM

Interface to calculation engine version: v5.4.0

BRUKL compliance check version: v5.4.b.0

## Owner Details

Name:

Telephone number:

Address: , ,

## Certifier details

Name: Levent Ulfet

Telephone number: 020 8150 8288

Address: The Enterprise Centre Cranborne Road, Potters Bar, EN6 3DQ

Criterion 1: The calculated CO<sub>2</sub> emission rate for the building must not exceed the target

The building does not comply with England Building Regulations Part L 2013

CO <sub>2</sub> emission rate from the notional building, kgCO <sub>2</sub> /m <sup>2</sup> .annum	98.2
Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	98.2
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	114.7
Are emissions from the building less than or equal to the target?	<b>BER &gt; TER</b>
Are as built details the same as used in the BER calculations?	Separate submission

## Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

## Building fabric

Element	U <sub>a</sub> -Limit	U <sub>a</sub> -Calc	U <sub>i</sub> -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.15	0.15	Level 02 - Reception B2312_W_8
Floor	0.25	0.15	0.15	Level 02 - Reception B2312_S_3
Roof	0.25	0.15	0.15	Level 02 - Reception B2312_R_5
Windows***, roof windows, and rooflights	2.2	1.4	1.4	Level 02 - GAIT B2322_G_11
Personnel doors	2.2	2.2	2.2	Level 02 - GAIT B2322_D_8
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"
U <sub>a</sub> -Limit = Limiting area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>a</sub> -Calc = Calculated area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>i</sub> -Calc = Calculated maximum individual element U-values [W/(m <sup>2</sup> K)]				
* There might be more than one surface where the maximum U-value occurs.				
** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.				
*** Display windows and similar glazing are excluded from the U-value check.				
N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air Permeability	Worst acceptable standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	10	10

## Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

<b>Whole building lighting automatic monitoring &amp; targeting with alarms for out-of-range values</b>	YES
<b>Whole building electric power factor achieved by power factor correction</b>	>0.95

### 1- VRF System

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.91	2.55	-	-	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

### 2- AHU 02 (via existing Boiler/CHP/Chiller)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.91	2.55	-	1.51	0.71
<b>Standard value</b>	0.91*	2.55	N/A	1.6^	0.5
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					
^ Limiting SFP may be extended by the amounts specified in the Non-Domestic Building Services Compliance Guide if the system includes additional components as listed in the Guide.					

### 3- AHU 01 (via existing Boiler/CHP/Chiller)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.91	2.55	-	1.6	0.71
<b>Standard value</b>	0.91*	2.55	N/A	1.6^	0.5
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					
^ Limiting SFP may be extended by the amounts specified in the Non-Domestic Building Services Compliance Guide if the system includes additional components as listed in the Guide.					

### 4- LST Radiators (via existing Boiler/CHP)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.91	-	-	-	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

### 1- HWS from CHP

	Water heating efficiency	Storage loss factor [kWh/litre per day]
<b>This building</b>	Hot water provided by HVAC system	-
<b>Standard value</b>	N/A	N/A

**Local mechanical ventilation, exhaust, and terminal units**

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
Level 04 - Theatre & MRI B4321		-	-	-	-	-	-	-	-	-	-	N/A
Level 04 - MRI Equipment B4304		-	-	-	-	-	-	-	-	-	-	N/A
Level 04 - Corridor B4300		-	-	-	-	-	-	-	-	-	-	N/A
Level 04 - IT Hub B4305		-	-	-	-	-	-	-	-	-	-	N/A
Level 04 - UPS B4308		-	-	-	-	-	-	-	-	-	-	N/A
Level 04 - LV Switch B4306		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Reception B2312		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - GAIT B2322		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Gym B2330		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Consult B2318		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Consult B2316		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Plaster Rm B2320		-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - MRI B3322		-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Anaesthetic Rm B3320		-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Control Rm B3324		-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Theatre B3314		-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Prep Rm B3312		-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Anaesthetic Rm B3318		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Corridor B2300		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - IT Hub B2302		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Disposal Rm B2304		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Changing B2306		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Store B2309		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Store B2310		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Store B2310		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Corridor B2314		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - WC B2324		-	-	0.5	-	-	-	-	-	-	-	N/A
Level 02 - Cleaners B2328		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Store B2331		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Store B2321		-	-	-	-	-	-	-	-	-	-	N/A
Level 02 - Store B2317		-	-	-	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency	
	A	B	C	D	E	F	G	H	I	Zone	Standard
<b>ID of system type</b>	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
<b>Standard value</b>	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
Level 02 - WC B2326	-	-	0.5	-	-	-	-	-	-	-	N/A
Level 03 - Corridor B3308	-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Dirty Utility B3310	-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Corridor B3306	-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Stairway B3ST-06	-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Metal Check B3326	-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - Sterile Store B3302	-	0.8	-	-	-	-	-	-	-	-	N/A
Level 03 - Corridor B3300	-	-	-	-	-	-	-	-	-	-	N/A
Level 03 - WC B3304	-	-	0.5	-	-	-	-	-	-	-	N/A

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name	Standard value	Luminaire	Lamp	Display lamp	
	60	60	22		
Level 04 - Theatre & MRI B4321	100	-	-	294	
Level 04 - MRI Equipment B4304	100	-	-	35	
Level 04 - Corridor B4300	-	100	-	48	
Level 04 - IT Hub B4305	100	-	-	23	
Level 04 - UPS B4308	100	-	-	32	
Level 04 - LV Switch B4306	100	-	-	52	
Level 02 - Reception B2312	-	83	83	356	
Level 02 - GAIT B2322	-	83	-	252	
Level 02 - Gym B2330	-	83	-	240	
Level 02 - Consult B2318	-	107	-	150	
Level 02 - Consult B2316	-	107	-	161	
Level 02 - Plaster Rm B2320	-	107	-	164	
Level 03 - MRI B3322	-	60	-	1673	
Level 03 - Anaesthetic Rm B3320	-	95	-	399	
Level 03 - Control Rm B3324	-	95	-	448	
Level 03 - Theatre B3314	-	95	-	1061	
Level 03 - Prep Rm B3312	-	95	-	357	
Level 03 - Anaesthetic Rm B3318	-	95	-	411	
Level 02 - Corridor B2300	-	82	-	59	
Level 02 - IT Hub B2302	106	-	-	18	
Level 02 - Disposal Rm B2304	107	-	-	26	
Level 02 - Changing B2306	-	106	-	24	
Level 02 - Store B2309	96	-	-	17	
Level 02 - Store B2310	96	-	-	103	
Level 02 - Store B2310	96	-	-	11	
Level 02 - Corridor B2314	-	82	-	50	
Level 02 - WC B2324	-	86	-	61	
Level 02 - Cleaners B2328	86	-	-	44	
Level 02 - Store B2331	107	-	-	51	
Level 02 - Store B2321	86	-	-	43	

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name		Luminaire	Lamp	Display lamp	General lighting [W]
	<b>Standard value</b>	60	60	22	
Level 02 - Store B2317		96	-	-	10
Level 02 - WC B2326		-	86	-	32
Level 03 - Corridor B3308		-	66	-	100
Level 03 - Dirty Utility B3310		95	-	-	53
Level 03 - Corridor B3306		-	66	-	78
Level 03 - Stairway B3ST-06		-	86	-	61
Level 03 - Metal Check B3326		-	95	-	330
Level 03 - Sterile Store B3302		95	-	-	92
Level 03 - Corridor B3300		-	66	-	86
Level 03 - WC B3304		-	86	-	44

### Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Level 02 - Reception B2312	N/A	N/A
Level 02 - GAIT B2322	NO (-79.1%)	NO
Level 02 - Gym B2330	NO (-81.6%)	NO
Level 02 - Consult B2318	NO (-60.3%)	NO
Level 02 - Consult B2316	NO (-39.5%)	NO
Level 02 - Plaster Rm B2320	NO (-65.8%)	NO
Level 03 - MRI B3322	N/A	N/A
Level 03 - Anaesthetic Rm B3320	N/A	N/A
Level 03 - Control Rm B3324	N/A	N/A
Level 03 - Theatre B3314	N/A	N/A
Level 03 - Prep Rm B3312	N/A	N/A
Level 03 - Anaesthetic Rm B3318	N/A	N/A
Level 03 - Metal Check B3326	N/A	N/A

### Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

### Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

### EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	YES

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Area [m <sup>2</sup> ]	880.7	880.7
External area [m <sup>2</sup> ]	2028.4	2028.4
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	10	3
Average conductance [W/K]	437.71	648.42
Average U-value [W/m <sup>2</sup> K]	0.22	0.32
Alpha value* [%]	80	10.49

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

	A1/A2 Retail/Financial and Professional services
	A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
	B1 Offices and Workshop businesses
	B2 to B7 General Industrial and Special Industrial Groups
	B8 Storage or Distribution
	C1 Hotels
<b>89</b>	<b>C2 Residential Institutions: Hospitals and Care Homes</b>
	C2 Residential Institutions: Residential schools
	C2 Residential Institutions: Universities and colleges
	C2A Secure Residential Institutions
	Residential spaces
	D1 Non-residential Institutions: Community/Day Centre
	D1 Non-residential Institutions: Libraries, Museums, and Galleries
	D1 Non-residential Institutions: Education
	D1 Non-residential Institutions: Primary Health Care Building
	D1 Non-residential Institutions: Crown and County Courts
<b>11</b>	<b>D2 General Assembly and Leisure, Night Clubs, and Theatres</b>
	Others: Passenger terminals
	Others: Emergency services
<b>1</b>	<b>Others: Miscellaneous 24hr activities</b>
	Others: Car Parks 24 hrs
	Others: Stand alone utility block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	50.93	48.64
Cooling	101.3	37.8
Auxiliary	55.31	68.8
Lighting	45.6	63.96
Hot water	6.29	6.29
Equipment*	248.18	248.18
<b>TOTAL**</b>	<b>259.43</b>	<b>225.5</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	769.61	737.95
Primary energy* [kWh/m <sup>2</sup> ]	675.07	577.57
Total emissions [kg/m <sup>2</sup> ]	114.7	98.2

\* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

## HVAC Systems Performance

System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
<b>[ST] No Heating or Cooling</b>									
<b>Actual</b>	113.6	2.8	0	0	0	0	0	0	0
<b>Notional</b>	62.5	16.7	0	0	0	0	0	----	----
<b>[ST] Split or multi-split system, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
<b>Actual</b>	268.4	166	83.5	24.2	0	0.89	1.91	0.91	2.55
<b>Notional</b>	216.8	347.8	73.5	26.8	0	0.82	3.6	----	----
<b>[ST] Constant volume system (fixed fresh air rate), [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
<b>Actual</b>	21.5	2674	6	519.1	191	1	1.43	0.91	2.55
<b>Notional</b>	28.5	2110.4	9.7	162.8	170.5	0.82	3.6	----	----
<b>[ST] Constant volume system (fixed fresh air rate), [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
<b>Actual</b>	186.9	1621.8	51.6	319.5	289.3	1.01	1.41	0.91	2.55
<b>Notional</b>	230.4	1439.7	78.2	111.1	432	0.82	3.6	----	----
<b>[ST] Central heating using water: radiators, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
<b>Actual</b>	233.8	168.1	75.9	0	4.4	0.86	0	0.91	0
<b>Notional</b>	194.1	282.4	65.8	0	4.9	0.82	0	----	----

### Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

# Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

## Building fabric

Element	U <sub>i-Typ</sub>	U <sub>i-Min</sub>	Surface where the minimum value occurs*
Wall	0.23	0.15	Level 02 - Reception B2312_W_8
Floor	0.2	0.15	Level 02 - Reception B2312_S_3
Roof	0.15	0.15	Level 02 - Reception B2312_R_5
Windows, roof windows, and rooflights	1.5	1.4	Level 02 - GAIT B2322_G_11
Personnel doors	1.5	2.2	Level 02 - GAIT B2322_D_8
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"
U <sub>i-Typ</sub> = Typical individual element U-values [W/(m <sup>2</sup> K)]		U <sub>i-Min</sub> = Minimum individual element U-values [W/(m <sup>2</sup> K)]	
* There might be more than one surface where the minimum U-value occurs.			

Air Permeability	Typical value	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	5	10