

---

**From:** Marnie Sommariva [REDACTED]  
**Sent:** 09 August 2019 11:42  
**To:** McClue, Jonathan  
**Cc:** Gary Brook  
**Subject:** RE: 101 Camley Street - Condition Update and Meeting Request

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Jonathan,

For condition 3(d) – External lighting (ref. 2019/1222/P) the dusk till dawn sensor will be used to control the external lighting at 101 Camley street. The specifications of the sensor are set out below.

For the details of the timings, all external lighting (except safety and security lighting) will be able to be automatically switched off between 23:00 and 07:00. Any safety or security lighting provided which will be used between 23:00 and 07:00 will comply with the lower levels of lighting recommended during these hours in Table 2 of the Institution of Lighting Professional's (ILPs) Guidance notes.

I trust this is sufficient to sign off condition 3(d), however do let me know if anything further is required. Thank you for your patience waiting for these details.

Kind regards,  
Marnie

***Dusk till Dawn Sensor Specifications***

- *Brand* CED
- *Colour* Black Body & Opal Head
- *Construction Material (Lighting)* Polycarbonate
- *Fitting Installation* Wall-Mounted
- *Fixings Supplied* Fixings Supplied
- *Hertz (Hz)* 50 Hz
- *IP Rating* IP54
- *Manufacturer Guarantee* 1 Year Guarantee
- *Pack Size* 1
- *Parent Colour* Black
- *Pieces in Pack/Case* 1
- *Power Source* Mains-Powered
- *Power Voltage Supply* 230-240 V
- *Product Depth* 85 mm
- *Product Height* 129 mm
- *Product Type* Standalone Photocell
- *Product Width* 85 mm
- *Sensor Type* Photocell
- *Switching Capacity (Fluorescent)* 500 W
- *Switching Capacity (Incandescent)* 1000 W
- *Wireless/Wired* Wired

Marnie Sommariva  
Planning Consultant  
Tel. [REDACTED]  
Mobile. + [REDACTED]

Gerald Eve LLP  
72 Welbeck Street, London, W1G 0AY  
www.geraldeve.com



**GERALDEVE**

