

Part 1/1

REPORT No: J000392/AA02

SITE ADDRESS: 138-140 Highgate Road, Highgate, London

CLIENT: Asbestos Essentials Limited

DATE	TIME	DETAILS
2019-08-16	07:54	R.Wareham of AC&MS arrives on site
2019-08-16	07:56	Liaise with R.Carter (Asbestos Essentials) supervisor to discuss scope of works, these are removal of A.I.B panels to ceiling under fully controlled conditions
2019-08-16	08:02	Stage 1 of re-occupation complete
2019-08-16	08:07	R.Wareham enters enclosure to commence visual inspection wearing 1no personal test
2019-08-16	09:51	1 o personal test taken off R.Wareham conducting visual inspection, result gave satisfactory reading <0.02f/ml
2019-08-16	10:29	3no clearance tests taken off, all results gave satisfactory reading <0.01f/ml
2019-08-16	11:13	Stage 4 of re-occupation complete
2019-08-16	11:36	R.Wareham leaves site