

**From:** [REDACTED]  
**Sent:** 05 September 2019 14:57  
**To:** Planning [REDACTED]  
**Subject:** 3rd Party Planning Application - 2019/4140/P

London Borough of Camden Our DTS Ref: 337  
Camden Town Hall Your Ref: 2019/4140/P  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

5 September 2019

Dear Sir/Madam

Re: 156, WEST END LANE, LONDON, NW6 1SD

Waste Comments

Water Comments

Thank you for consulting Thames Water for the discharge of matters relating to piling near a strategic water main. Thames Water is unable to support the discharge of this condition for the reasons outlined below.

Supplementary Comments

The documents submitted indicate that the developer is intending to carry out piling works within exclusion zones of Thames Water assets. The developer is required to contact the Thames Water Developer Services department and state that they have been referred to the Asset Protection team by the Development Planning team to discuss the requirements for an asset protection study (0800 009 3921 or by email at [developer.services@thameswater.co.uk](mailto:developer.services@thameswater.co.uk), FAO Asset Protection). Their case will be logged and a representative from the Asset Protection team will be in contact with them.

More details on the asset protection impact study process can be found in the guidance document "Working Near Our Assets" (available online at <https://developers.thameswater.co.uk/developing-a-large-site/planning-your-development/working-near-or-diverting-our-pipes>).

Plans of Thames Water apparatus can be obtained through our website at [www.thameswater-propertysearches.co.uk](http://www.thameswater-propertysearches.co.uk). Please contact Developer Services if you wish to discuss further (0800 009 3921 or by email at [developer.services@thameswater.co.uk](mailto:developer.services@thameswater.co.uk)). Please use the following reference in all future correspondence: DTS 337.

Please bear in mind that Thames Water will hold the developer and any relevant

contractor/sub-contractor liable for any losses incurred or damage caused to Thames Water assets arising from construction works or subsequent use of the facility.

Yours faithfully  
Development Planning Department



This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to



Visit us online [www.thameswater.co.uk](http://www.thameswater.co.uk) , follow us on twitter [www.twitter.com/thameswater](https://twitter.com/thameswater) or find us on [www.facebook.com/thameswater](https://www.facebook.com/thameswater). We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.