

Conservation Area Advisory Committee

Advisory Committee

Application ref	2019/4041/P
Address	126 Mansfield Road London NW3 2JB
Planning Officer	Alyce Jeffery
Comments by	24 Sep 2019
Proposal	Erection of a rear dormer roof extension; and installation of two rooflights to the front roof slope.
Objection	Yes
Observations	The proposed rear dormer is far too big notwithstanding other examples which pre-date the CA. The section over the stairs would appear less useful and might be lost in a new design. A smaller dormer with no vertical side facings and no apron below the cill would be acceptable.

Documents attached

No details entered

About this form

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
Form reference	21513938

Data Protection

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can request that this does not happen.