

106-108 Regents Park Road
NW1 8UG

Basement Impact Assessment
Audit

For
London Borough of Camden

Project Number: 12985-72
Revision: D1

September 2019

Campbell Reith Hill LLP
Friars Bridge Court
41-45 Blackfriars Road
London
SE1 8NZ

T: +44 (0)20 7340 1700
F: +44 (0)20 7340 1777
E: london@campbellreith.com
W: www.campbellreith.com

Document History and Status

Revision	Date	Purpose/Status	File Ref	Author	Check	Review
D1	Sept 2019	Comment	ASPgk-12985-72-060919 106-108 Regents Park Rd-D1.doc	ASP	GK	GK

This document has been prepared in accordance with the scope of Campbell Reith Hill LLP's (CampbellReith) appointment with its client and is subject to the terms of the appointment. It is addressed to and for the sole use and reliance of CampbellReith's client. CampbellReith accepts no liability for any use of this document other than by its client and only for the purposes, stated in the document, for which it was prepared and provided. No person other than the client may copy (in whole or in part) use or rely on the contents of this document, without the prior written permission of Campbell Reith Hill LLP. Any advice, opinions, or recommendations within this document should be read and relied upon only in the context of the document as a whole. The contents of this document are not to be construed as providing legal, business or tax advice or opinion.

© Campbell Reith Hill LLP 2015

Document Details

Last saved	06/09/2019 12:37
Path	ASPgk-12985-72-060919 106-108 Regents Park Rd-D1.doc
Author	A Pontes, CEng MICE
Project Partner	E M Brown, BSc MSc CGeol FGS
Project Number	12985-72
Project Name	106-108 Regents Park Road
Planning Reference	2019/0194/P

Contents

1.0 Non-technical summary 1

2.0 Introduction 3

3.0 Basement Impact Assessment Audit Check List..... 5

4.0 Discussion 8

5.0 Conclusions 10

Appendix

- Appendix 1: Residents' Consultation Comments
- Appendix 2: Audit Query Tracker
- Appendix 3: Supplementary Supporting Documents

1.0 NON-TECHNICAL SUMMARY

- 1.1. CampbellReith was instructed by London Borough of Camden, (LBC) to carry out an audit on the Basement Impact Assessment submitted as part of the Planning Submission documentation for 106-108 Regents Park Road, London, NW1 8UG (planning reference 2019/0194/P). The basement is considered to fall within Category B as defined by the Terms of Reference.
- 1.2. The Audit reviewed the Basement Impact Assessment for potential impact on land stability and local ground and surface water conditions arising from basement development in accordance with LBC's policies and technical procedures.
- 1.3. CampbellReith was able to access LBC's Planning Portal and gain access to the latest revision of submitted documentation and reviewed it against an agreed audit check list.
- 1.4. The Basement Impact Assessment (BIA) authors hold suitable qualifications.
- 1.5. The basement proposal does not involve nor is adjacent to a listed building.
- 1.6. The proposed development comprises lowering the existing lower ground floor level and rear garden, erection of rear extensions at lower ground, ground and first floor levels, and partial front infill extension.
- 1.7. Site specific ground investigations indicate the presence of shallow Made Ground over London Clay.
- 1.8. Perched water was recorded during monitoring. However, the proposed development will not impact upon the wider hydrogeological environment.
- 1.9. It is proposed to use underpinning techniques to facilitate the development. Outline structural information has been provided. The underpinning sequence and proposed bearing pressures should be clarified.
- 1.10. The interpretative geotechnical assessment should be clarified, including provision of retaining wall design parameters. An assessment of settlement should be made at the proposed bearing pressures.
- 1.11. A Ground Movement Assessment has been undertaken. The damage to neighbours is assessed as being Category 1 (Very Slight) in accordance with the Burland Scale. This should be confirmed once structural information is clarified, as 1.9, and bearing pressures / settlements have been assessed, as 1.10.

- 1.12. Based on the current GMA, very limited movements will impact the highway and underlying utilities. This should be confirmed, as 1.11. If movements significantly increase, utilities information should be obtained and impacts assessed. Asset protection criteria should be agreed with asset owners, as applicable.
- 1.13. A monitoring strategy is outlined, including targets locations and trigger values. The monitoring strategy should be adopted and agreed under the party Wall Act.
- 1.14. There will be a reduction of impermeable site area as a result of the proposed development. The proposed works will not impact the wider hydrological environment. A final drainage design should be agreed with LBC and Thames Water.
- 1.15. The site is within the Primrose Hill Local Flood Risk Zone. A Flood Risk Assessment has been undertaken and the site is classified as being at low risk of flooding. Standard flood risk mitigation measures should be adopted within the final design.
- 1.16. An outline construction programme should be presented.
- 1.17. Queries and requests for information are discussed in section 4 and summarised in appendix 2. Until the additional information requested is provided, the BIA does not meet the requirements of CPG: Basements.

2.0 INTRODUCTION

- 2.1. CampbellReith was instructed by London Borough of Camden (LBC) on 1st August 2019 to carry out a Category B Audit on the Basement Impact Assessment (BIA) submitted as part of the Planning Submission documentation for 106-108 Regents Park Road, London, NW1 8UG planning reference 2019/0194/P.
- 2.2. The Audit was carried out in accordance with the Terms of Reference set by LBC. It reviewed the Basement Impact Assessment for potential impact on land stability and local ground and surface water conditions arising from basement development.
- 2.3. A BIA is required for all planning applications with basements in Camden in general accordance with policies and technical procedures contained within
- Guidance for Subterranean Development (GSD). Issue 01. November 2010. Ove Arup & Partners.
 - Camden Planning Guidance Basements. March 2018.
 - Camden Development Policy (DP) 27: Basements and Lightwells.
 - Camden Development Policy (DP) 23: Water.
 - Local Plan Policy A5 Basements.
- 2.4. The BIA should demonstrate that schemes:
- a) maintain the structural stability of the building and neighbouring properties;
 - b) avoid adversely affecting drainage and run off or causing other damage to the water environment;
 - c) avoid cumulative impacts upon structural stability or the water environment in the local area, and;
 - d) evaluate the impacts of the proposed basement considering the issues of hydrology, hydrogeology and land stability via the process described by the GSD and to make recommendations for the detailed design.
- 2.5. LBC's Audit Instruction described the planning proposal as *"Erection of rear extensions at lower ground, ground and first floor levels; partial front infill extension at lower ground floor level; lowering of floor level throughout; and other external changes including fenestration alterations and reinstatement of garden wall in association with reconfiguration of building into single dwelling house (5-bed) and two self-contained units (1x1-bed; 1x2-bed) (C3)".*

2.6. CampbellReith accessed LBC's Planning Portal on 15th August 2019 and gained access to the following relevant documents for audit purposes:

- Basement Impact Assessment Report (BIA) by TWS, ref. 9439_SL_GB_BIA rev. 1.0, 14th June 2019.
- Planning Application Architectural Drawings consisting of:
 - Existing Lower Ground Floor Plan, 1939 E-101
 - Existing Ground Floor Plan, 1939 E-102
 - Existing First and Second Floor Plan, 1939 E-103
 - Existing Third Floor and Roof Plan, 1939 E-104
 - Existing Front and Rear Elevation, 1939 E-111
 - Existing Section AA, 1939 E-121
 - Existing Section DD, 1939 E-122
 - Proposed Lower Ground Floor Plan_rev A, 1939 P-201
 - Proposed Ground Floor Plan_rev A, 1939 P-202
 - Proposed Elevations_rev A, 1939 P-211
 - Proposed Section AA_rev A, 1939 P-221
 - Proposed Section BB_rev A, 1939 P-222
 - Proposed Section CC_rev A, 1939 P-223
 - Proposed Section DD_rev A, 1939 P-224
 - Proposed Section EE_rev A, 1939 P-225
- Planning Comments and Consultation Responses.

3.0 BASEMENT IMPACT ASSESSMENT AUDIT CHECK LIST

Item	Yes/No/NA	Comment
Are BIA Author(s) credentials satisfactory?	Yes	Refer to section 1.3 of the BIA
Is data required by Cl.233 of the GSD presented?	No	Construction programme, utilities records to be provided.
Does the description of the proposed development include all aspects of temporary and permanent works which might impact upon geology, hydrogeology and hydrology?	Yes	Information indicated in Section 2
Are suitable plan/maps included?	Yes	Refer to Appendix N of the BIA
Do the plans/maps show the whole of the relevant area of study and do they show it in sufficient detail?	Yes	
Land Stability Screening: Have appropriate data sources been consulted? Is justification provided for 'No' answers?	Yes	Answer to question 6 is incorrect. The proposed works are close to a tree. An arboricultural assessment was completed, refer to appendix O of the BIA.
Hydrogeology Screening: Have appropriate data sources been consulted? Is justification provided for 'No' answers?	Yes	Refer to section 1.19 of the BIA
Hydrology Screening: Have appropriate data sources been consulted? Is justification provided for 'No' answers?	Yes	Refer to section 1.19 of the BIA
Is a conceptual model presented?	Yes	
Land Stability Scoping Provided? Is scoping consistent with screening outcome?	Yes	Refer to section 2 and appendix J of the BIA

Item	Yes/No/NA	Comment
Hydrogeology Scoping Provided? Is scoping consistent with screening outcome?	Yes	Refer to section 3 and appendix J of the BIA
Hydrology Scoping Provided? Is scoping consistent with screening outcome?	Yes	Refer to section 4
Is factual ground investigation data provided?	Yes	Refer to appendix L of the BIA
Is monitoring data presented?	Yes	Refer to section 3 of the BIA, appendix L
Is the ground investigation informed by a desk study?	Yes	
Has a site walkover been undertaken?	Yes	Refer to section 1.7 of the BIA
Is the presence/absence of adjacent or nearby basements confirmed?	Yes	Refer to appendices E and F of the BIA
Is a geotechnical interpretation presented?	Yes	Insufficient; refer to Appendix G3 GSD
Does the geotechnical interpretation include information on retaining wall design?	No	Refer to Appendix G3 GSD
Are reports on other investigations required by screening and scoping presented?	Yes	Ground movement and hydrogeological assessments in appendix J of the BIA, and arboricultural report in appendix O of the BIA
Are the baseline conditions described, based on the GSD?	Yes	Refer to section 1 of the BIA
Do the base line conditions consider adjacent or nearby basements?	Yes	
Is an Impact Assessment provided?	Yes	Ground movement and hydrogeological assessments in appendix J, arboricultural report in appendix O, and surface water appraisal in section 4 of the BIA

Item	Yes/No/NA	Comment
Are estimates of ground movement and structural impact presented?	Yes	Refer to appendix J of the BIA
Is the Impact Assessment appropriate to the matters identified by screen and scoping?	No	Interpretative geotechnical parameters and settlement assessment at specific bearing pressure required to confirm GMA
Has the need for mitigation been considered and are appropriate mitigation methods incorporated in the scheme?	No	Interpretative geotechnical parameters and settlement assessment at specific bearing pressure required to confirm GMA
Has the need for monitoring during construction been considered?	Yes	Refer to appendix I
Have the residual (after mitigation) impacts been clearly identified?	No	Interpretative geotechnical parameters and settlement assessment at specific bearing pressure required to confirm GMA
Has the scheme demonstrated that the structural stability of the building and neighbouring properties and infrastructure will be maintained?	No	Interpretative geotechnical parameters and settlement assessment at specific bearing pressure required to confirm GMA
Has the scheme avoided adversely affecting drainage and run-off or causing other damage to the water environment?	Yes	Refer to section 4.0 of the BIA
Has the scheme avoided cumulative impacts upon structural stability or the water environment in the local area?	No	Interpretative geotechnical parameters and settlement assessment at specific bearing pressure required to confirm GMA
Does report state that damage to surrounding buildings will be no worse than Burland Category 1?	Yes	Interpretative geotechnical parameters and settlement assessment at specific bearing pressure required to confirm GMA
Are non-technical summaries provided?	Yes	Executive Summary

4.0 DISCUSSION

- 4.1. The Basement Impact Assessment (BIA) has been carried out by a firm of engineering consultants, Taylor Whalley Spyra (TWS) and the Ground Movement Assessment (GMA) and hydrogeological assessment were produced by a geotechnical consultancy firm, Geotechnical Consulting Group (GCG). All individuals concerned in its production have suitable qualifications.
- 4.2. The basement proposal does not involve nor is adjacent to a listed building.
- 4.3. The proposed development comprises lowering the existing lower ground floor level and rear garden, erection of rear extensions at lower ground, ground and first floor levels, and partial front infill extension.
- 4.4. The proposed basement is not in the vicinity of any TFL infrastructure, water body or historic rivers. The BIA also identifies neighbouring basements and assumed foundation levels.
- 4.5. Site specific ground investigation has been carried out. The site investigation indicates that the ground conditions comprise Made Ground (to maximum 0.6m bgl) overlying weathered London Clay (proven to 7.0m bgl). Water was recorded within borehole installations during two monitoring visits. This water was considered to be perched water within the Made Ground and / or a result of surface run-off.
- 4.6. Considering the existing depth of foundations, which penetrate the Made Ground and effectively block any perched water flow, and the classification of the London Clay as unproductive strata, the proposed development will not impact upon the wider hydrogeological environment. It is recommended that further groundwater monitoring is undertaken prior to final design and construction to inform temporary works strategies and ensure stability is maintained. As indicated in the hydrogeological assessment, all relevant structural elements should be designed taking into account hydrostatic pressures.
- 4.7. It is proposed to use underpinning techniques to facilitate the development. Outline structural information has been provided. The underpinning sequence should be clarified. For instance, it is indicated on drawing "BIA_03" that consecutive bays have been sequenced.
- 4.8. Although it is generally accepted that mass concrete underpinning in conjunction with a reinforced concrete slab, to resist horizontal loads, is adequate where the ground is being lowered 700mm, this is queried for the section next to the garage (drawing number BIA_03, sections C-C and D-D) and where the underpinning is proposed under a free-standing wall (drawing number BIA_03, sections F-F and G-G). The retaining wall designs indicating the deflections should be provided to ensure consistency with the GMA assumptions.
- 4.9. The proposed bearing pressures should be clarified.

- 4.10. A limited geotechnical interpretation has been provided, indicating a range of allowable bearing capacities. Complete geotechnical information should be provided, as Appendix G3 of the GSD, including retaining wall design parameters. An assessment of settlement should be made at the proposed bearing pressures to ensure consistency with the GMA.
- 4.11. The GMA has been undertaken broadly in accordance with CIRIA C760 and the potential damage to the neighbouring structures was assessed. Whilst the CIRIA approach is intended for embedded retaining walls, it is accepted that the predicted ground movements are consistent with the range typically anticipated for underpinning techniques carried out with good control of workmanship.
- 4.12. The damage to neighbours is assessed as being Category 1 (Very Slight) in accordance with the Burland Scale. This should be confirmed once bearing pressures / settlements have been assessed, as 4.10, and once the structural design has been confirmed, as 4.7 and 4.8.
- 4.13. Based on the current GMA, very limited movements will impact the highway and underlying utilities. This should be confirmed, as 4.12. If movements significantly increase, utilities information should be obtained and impacts assessed. Asset protection criteria should be agreed with asset owners, as applicable.
- 4.14. A monitoring strategy is outlined, including targets locations and trigger values. The monitoring strategy should be adopted and agreed under the party Wall Act. Review may be needed, following any revision of the GMA.
- 4.15. There will be a reduction of 9m² in impermeable area, as a result of the proposed development. The proposed works will not impact the wider hydrological environment. A final drainage design should be agreed with LBC and Thames Water.
- 4.16. The site is within the Primrose Hill Local Flood Risk Zone. A Flood Risk Assessment has been undertaken and the site is classified as being at low risk of flooding. Thames Water was consulted regarding sewer flooding and it was confirmed that there have been no incidents in the area. Standard flood risk mitigation measures should be adopted within the final design.
- 4.17. An arboricultural impact assessment was undertaken to estimate the impact of the proposal in regard to the existing tree to the front of 106 Regent's Park Road. It concluded that the potential impacts are not significant as long as suitable mitigation measures and supervision are put in place, as detailed in the report. Due to the position of the tree relative to existing structures and the proposed works, the presence of the tree should not impact upon the proposed foundations or the foundations of neighbouring structures.
- 4.18. An outline construction programme should be presented.

5.0 CONCLUSIONS

- 5.1. The BIA authors hold suitable qualifications.
- 5.2. Site specific ground investigations indicate the presence of shallow Made Ground over London Clay.
- 5.3. The proposed development will not impact upon the wider hydrogeological environment.
- 5.4. Structural and geotechnical information should be clarified, as detailed in Section 4.
- 5.5. Ground movements and consequential damage impacts should be clarified following review of the revised structural and geotechnical information, as detailed in Section 4.
- 5.6. Following review of the GMA, as 5.5, if movements significantly increase, utilities information should be obtained and impacts assessed. Asset protection criteria should be agreed with asset owners, as applicable.
- 5.7. A monitoring strategy is outlined, including targets locations and trigger values. The monitoring strategy should be adopted and agreed under the party Wall Act.
- 5.8. The proposed works will not impact the wider hydrological environment. A final drainage design should be agreed with LBC and Thames Water.
- 5.9. A Flood Risk Assessment has been undertaken and the site is classified as being at low risk of flooding. Standard flood risk mitigation measures should be adopted within the final design.
- 5.10. An outline construction programme should be presented.
- 5.11. Queries and requests for information are summarised in Appendix 2. Until the additional information requested is provided, the BIA does not meet the requirements of CPG: Basements.

Appendix 1: Residents' Consultation Comments

Residents' Consultation Comments

Surname	Address	Date	Issue raised	Response
Lubner	-	07.03.2019	No Basement Impact Assessment (BIA) was carried out.	The applicant produced a BIA. Report reference 9439_SL_GB_BIA, 14 th June 2019. The current report is an audit of the BIA presented.
Simpson (Primrose Hill CAAC)	-	10.03.2019	1. Impact on existing structure foundations. 2. Impact on tree of number 106 garden.	Queries discussed in Section 4. An arboricultural report was produced which concluded that the impacts on the tree are negligible if the appropriate protective measures are put in place.
Greene	-	28.02.2019	Stability of surrounding properties; impact on groundwater levels; impact on tree (number 106 Garden)	Queries discussed in Section 4.
Jolles	110 Regents Park Road	08.03.2019	No Basement Impact Assessment (BIA) was carried out. Stability of surrounding properties; impact on groundwater levels; impact on tree (number 106 Garden)	The applicant produced a BIA. Report reference 9439_SL_GB_BIA, 14 th June 2019. The current report is an audit to the BIA presented. Queries discussed in Section 4.

Appendix 2: Audit Query Tracker

Audit Query Tracker

Query No	Subject	Query	Status	Date closed out
1	BIA	Utilities information should be provided.	Open	
2	BIA	Outline construction programme should be provided.	Open	
3	Land Stability	Structural information should be clarified as 4.7, 4.8 and 4.9.	Open	
4	Land Stability	Geotechnical information should be clarified, as 4.10.	Open	
5	Land Stability	The GMA should be reviewed and updated, as 4.12 and 4.13.	Open	

Appendix 3: Supplementary Supporting Documents

None

London

Friars Bridge Court
41- 45 Blackfriars Road
London, SE1 8NZ

T: +44 (0)20 7340 1700
E: london@campbellreith.com

Birmingham

Chantry House
High Street, Coleshill
Birmingham B46 3BP

T: +44 (0)1675 467 484
E: birmingham@campbellreith.com

Surrey

Raven House
29 Linkfield Lane, Redhill
Surrey RH1 1SS

T: +44 (0)1737 784 500
E: surrey@campbellreith.com

Manchester

No. 1 Marsden Street
Manchester
M2 1HW

T: +44 (0)161 819 3060
E: manchester@campbellreith.com

Bristol

Wessex House
Pixash Lane, Keynsham
Bristol BS31 1TP

T: +44 (0)117 916 1066
E: bristol@campbellreith.com

UAE

Office 705, Warsan Building
Hessa Street (East)
PO Box 28064, Dubai, UAE

T: +971 4 453 4735
E: uae@campbellreith.com

Campbell Reith Hill LLP. Registered in England & Wales. Limited Liability Partnership No OC300082
A list of Members is available at our Registered Office at: Friars Bridge Court, 41- 45 Blackfriars Road, London SE1 8NZ
VAT No 974 8892 43