















1:50 @ A1

**NOTE.**  
FOR TYPICAL DETAILS REFER TO DRG. Nos.  
MHA-ACM-XX-XX-DE-S-00001 TO 00003.

	DENOTES NEW BRICKWORK TO MATCH EXISTING AND TO BE FULLY TOOTHED INTO EXISTING.
	DENOTES NEW STEEL BEAMS. SBX = 150x150x32UCJ27 WITH 50mm Deep x wall width TIMBER PLATE BOLTED TO TOP. USE M10 BOLTS AT 500mm STAGGERED CENTRES.
	DENOTES NEW STEEL BEAMS. SBY = 203x203x04UC6 LINTEL REPLACEMENT. EXISTING LINTEL REMOVED AND REPLACED WITH STEEL BEAM SUPPORTING STEEL FRAME OVER. REFER TO DETAIL X ON DRAWINGS MHA-ACM-WW-XX-DE-S-00001 & 2
	DENOTES EXISTING STEEL BEAMS.
	DENOTES EXTENT OF DEMOLITION. FOR DEMOLITION PLANS REFER TO ARCHITECTS DRAWINGS.
	DENOTES NEW PRESTRESSED CONCRETE LINTELS. NUMBER TO SUIT WALL THICKNESS. REFER TO DETAIL 1.
	DENOTES NEW PROPRIETARY SEGMENTAL ARCHED LINTEL BY HARVEY LINTELS, OR SIMILAR APPROVED. FOR FACING BRICKWORK WITH PRESTRESSED CONCRETE LINTELS BEHIND. NUMBER TO SUIT WALL THICKNESS.
	
	DENOTES NEW MASS CONCRETE PADSTONE. REFER TO DETAIL 3. ALLOW 450x150x150 DP TBC
	DENOTES NEW PARTY WALL PARTITIONS. REFER TO ARCHITECTS DETAILS.
	DENOTES NEW TIMBER JOISTS. 175x40 @400 CTR UNLESS NOTED OTHERWISE. (GRADE C24)
	REFER TO TYPEICAL LATERAL RESTRAINT DRG. MHA-ACM-XX-XX-DE-S-00002.