

FIXED TRAY MATERIAL: 20 SWG 316L 28 STAINLESS STEEL

(T) DRAIN CONNECTION TYPE: 3/4" BSP STAINLESS STEEL (AHS)

TRAY TYPE: HTM 1 (DP2) — STAINLESS TRAY & GALVANISED COVER

DRAIN TRAP : POSITIVE TRAP REQUIRED - SUPPLIED BY OTHERS

(6) DRAIN TRAP SEAL (X) = 140mm

DRAIN TRAP DOES EXCEED BASE DIMENSIONS - SITE MODIFICATION MAY BE REQUIRED BULKHEJO LIGHTS PREWIRED TO A COMMON EXTERNAL IP66 SWITCH PER UNIT,

(S) INSTALLATION TO COMPLY WITH 857671 IET REGULATIONS.

LIGHT: GLS (LED TYPE) PART No : EC-LED5.5W CABLE : SY (STANDARD)

(14) LOW LOSS GALVANISED STEEL OPPOSED BLADE DAMPER CONTROL: MOTORISED BY OTHERS

FOR MOTOR WRED TO SOLATOR ONLY — AHU MOTOR PREWRED TO AN IP66 EXTERNAL ISOLATOR, INSTALLATION TO COMPLY WITH B57671 IET REGULATIONS — CABLE TYPE: SY (STANDARD)

BASE MATERIAL: 150x75 P.F.C - FULL PERIMETER

FILTER WITHDRAWAL TYPE : SIDE WITHDRAWAL

AHU CONNECTION MANUFACTURED FROM 30mm GALVANISED STEEL MEZ FLAWGE FILISH MAINTED 0-250 PA PRESSIRE GAUGE & FIDNG - PART No : PC-DPG2-5000-250 SUPPLY FAM WREDLESH DOOR GLARD : 550mm X 1015mm (MuH)

FAN TOPHATS REQUIRED (SUPPLY) - 100mm Wide x 38mm High 14 Gauge

MOTOR THERMISTOR WIRED: TO EXTERNAL JUNCTION BOX — KIT PART: EC-GW4420: #215mm POLYCARBONATE VIEWPORT: KIT PART — PCOBPO35

UNIT APPROX. TOTAL WEIGHT: 1562Kgs

(+/- 10%)

PLEASE REFER TO OFFICE FOR FURTHER DETAILS FACTORY ASSEMBLED SECTIONS TO BE FIXED TOGETHER AND BASE STEELS FIXED TO UNIT FRAME

AIR ON AIR OFF FACE VELOCITY AIR PRESS, DROP DUTY

MODEL TYPE: FRAMELESS CONTSTRUCTION
 OUTER PANEL: HDX GRANTE ANTHRACITE
 INNER PANEL: WHITE ENAMEL
 PANEL INFILL TYPE: FOAM (45Kg/m3)

CONSTRUCTION & FINISH

door hinge type : Universal compression hinge (so = safety catch fitted) paint code : NCP/S2 - base/les colour : Matt black hox grante anth-pagite steel roof fitted (time pitched type)

UNIT WEIGHT & DIMENSIONS

AHU SUPPLIED TO SITE IN : TWO SECTIONS

AHU LOCATION : EXTERNAL UNIT

SECTIONS SIZE (Wated - mm) WEIGHT (Kgs)

728 834

SIZES EXCLUDE COIL CONNECTIONS AND ELECTRICAL COMPONENTS

IT BY BEDAM, OF SMALE PIECE OLDS CLEANANT REQUIRED SHALD EDM, OR BE GETER THAN THE WITH OF THE AMIL SHALL SH

:::::::

This document is the sole property of Air Handling Systems Limited (AHS) and is loaned only upon condition that it is not to be copied or reproduced nor to be used for furnishing information to others or any other purpose detrimental to the interest of AHS. WITREE: AHU 2 SOUTH SUPPLY ROJECT: GOSH ITALIAN HOSPITAL WINDEY: GM NUMBER: INTEGRAL UK LTD. 1:15 @ A1 4010-17875-3 **BNG:** STEVEN YALE nnovation through heritage 08/05/19 CHK BY:

P

MANUFACTURING NOTES
ALL FIXED PANELS SECURED WITH DRILL SCREWS EXTERNAL TO AND UNLESS SPECIFED.
AND MANUFACTURED IN ACCORDANCE WITH HE/MC DWI 43 CLASS C & BS EN 1886 LT.

W : ahs.uk.com

T: +44 (0)1388 776287