
NEW OXFORD STREET

WEST CENTRAL STREET

route prove			Green line denotes th
			Blue line denotes area performance of a play Red line denotes area alcohol, including regunight refreshments.
Note a damage	FIRE SAFETY REQUIREMENTS		The position of fire saf the plan or such positi in consultation with the
	00 ILLUMINATED EMERGENCY EXIT SIGN (MAINTAINED)	CO2 CARBON DIOXIDE EXTINGUISHER	PANIC BOLTS 'PUSH BAR TO OPEN ' NOTICE TO BE FITTED ABOVE THE PUSH BAR IN 50mm HIGH WHITE LETTERING ON GREEN BACKGROUND. PUSH BARS FITTED BETWEEN 900mm & 1100mm
	EMERGENCY LIGHT FITTINGS		ABOVE FINISHED FLOOR LEVEL FASTENINGS INSTALLED TO B.S.5725 : PART 1 : 1981
		WATER EXTINGUISHER	N3 NOTICE 'FIRE DOOR KEEP LOCKED SHUT 'IN 50mm HIGH WHITE LETTERING ON BLUE BACKGROUND.
LET CET	SD SMOKE DETECTOR HEAT DETECTOR SD SMOKE DETECTOR WITH SOUNDER	N1 FIRE PROCEDURE NOTICE   B FIRE BLANKET	NOTICE 'FIRE DOOR KEEP SHUT' IN 50mm HIGH WHITE LETTERING ON BLUE BACKGROUND.
GTRE	SD SMOKE DETECTOR WITH SOUNDER	Fire resisting door	
RAL	HD HEAT DETECTOR WITH SOUNDER	FP FIRE ALARM PANEL	NOTICE 'FIRE DOOR KEEP CLEAR' IN 50mm HIGH WHITE LETTERING ON BLUE BACKGROUND.
CENT	FIRE ALARM CALL POINT		
LIST U.			VP VISION PANEL IN DOOR
WEST CENTRAL STREET			

THIS DRAWING HAS BEEN PRODUCED FROM EXISTING AND PROPOSED DRAWINGS SUPPLIED BY THE CLIENT INDICATING THE POSITIONS OF THE EMERGENCY LIGHTING AND FIRE DETECTION SYSTEM.



s the extent of the premises.

rea to be used for the lay.

MUSEUM

STREET

ea to be used for the sale of egulated entertainment and late

safety equipment as shown on sition as agreed from time to time the fire authority.

EMERGENCY LIGHTS The emergency lighting system which must illuminate the escape route if the mains supply fails, must be fitted in accordance with B.S.5266

FIRE ALARM The fire alarm system should comply with B.S.5839. Part 1 1988 and should be audible throughout the building

Fire fighting Equipment. 9 litre water type fire extinguisher. 4.5kg. capacity (34B rating) carbon dioxide content extinguisher. Extinguishers to be placed on wall brackets so that the top of the extinguisher is about 1m above floor. An approved fire blanket and container should be provided for the kitchen

Fire exit signs conforming to the requirements of B.S.5499 Directional fire exit signs conforming to the requirements of B.S.5499 to be positioned at each change of direction or each part escape route where the exit doors are not readily visible to persons using the escape route.

## Thomas Moss

Architectural Design and Surveying Services Summit House, Horsecroft Road, The Pinnacles, Harlow, Essex. CM19 5BN Tel: 07702 477199 E-Mail: tmoss@pembrook.co.uk

Client: LABTECH INVESTMENTS LTD

Project:

SELKIRK HOUSE 166 HIGH HOLBORN LONDON

Drawing Title: LICENSING DRAWING MEZZANINE FLOOR LAYOUT

Drawing No: 251/19/03 Scale: 1:100@A1 & 1:200@A3 Date: 3.9.2019

Drawn By: TAM

Revision:

Drawing not to be scaled. Dimensions indicated must be checked on site before manufacture by contractor, any discrepancy should be reported immediately.