



### Sample/Benchmark Approval

Form: 300-43  
Rev: 1

Project:	T-Zone	Project No:	HLN.0271
Submitted by:	Structural Stairways	Date:	10.05.19
Submitted to:	Bennetts DT, Bennetts CMT	Ref No:	124
Type:	Sample: <input checked="" type="checkbox"/>	Benchmark: <input type="checkbox"/>	Mock-up: <input type="checkbox"/>
Metal Blank Door West Elevation			
Location for Inspection: Site office		Storage Location after Inspection: (must be suitable) Site office	
To be Built into the Works?		If YES Location:	
<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		<input type="text"/>	
Applicable Certification(s) (e.g. BS, BBA cert etc)			
Purpose: Approval			
Project Team Comments: <i>Mitre where marked to be fitted tight. Folded corner filler visible. Colour to be RAL 1035 as per BAM sample 120.</i>			
Approval Status		Re-submittal Date Required	
A <input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/>		<input type="text"/>	
<i>Legend: A - Approved; B - Approved with Comments; C - Rejected</i>			
<b>Sample Approved By:</b>			
Signed: <i>[Signature]</i>	Name: <i>Alan Come</i>	of: <i>Bennetts CMT</i>	Date: <i>28.05.19</i>
Signed: <i>[Signature]</i>	Name: <i>John Wilson</i>	of: <i>Bennetts CMT</i>	Date: <i>28.05.2019</i>
Signed: _____	Name: _____	of: _____	Date: _____
Distribution	Client <input checked="" type="checkbox"/>	Arch <input checked="" type="checkbox"/>	Other (specify) G+T CMT

