


tIDC Ltd		Page 1
48 West End Westbury Wiltshire BA13 3JG	MBP-7764 62 Avenue Road Attenuation Storage	
Date July 2019 File Attenuation+Hydrobrake.SRCX	Designed by Peter White Checked by	
Micro Drainage	Source Control 2016.1	

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 32 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max Σ Outflow (l/s)	Max Volume (m ³)	Status
15 min Summer	99.297	0.797	0.0	5.0	5.0	13.2	O K
30 min Summer	99.403	0.903	0.0	5.0	5.0	15.0	O K
60 min Summer	99.394	0.894	0.0	5.0	5.0	14.9	O K
120 min Summer	99.269	0.769	0.0	5.0	5.0	12.8	O K
180 min Summer	99.104	0.604	0.0	5.0	5.0	10.0	O K
240 min Summer	98.968	0.468	0.0	5.0	5.0	7.8	O K
360 min Summer	98.785	0.285	0.0	5.0	5.0	4.7	O K
480 min Summer	98.687	0.187	0.0	4.7	4.7	3.1	O K
600 min Summer	98.637	0.137	0.0	4.3	4.3	2.3	O K
720 min Summer	98.615	0.115	0.0	3.9	3.9	1.9	O K
960 min Summer	98.593	0.093	0.0	3.2	3.2	1.5	O K
1440 min Summer	98.573	0.073	0.0	2.3	2.3	1.2	O K
2160 min Summer	98.559	0.059	0.0	1.6	1.6	1.0	O K
2880 min Summer	98.552	0.052	0.0	1.3	1.3	0.9	O K
4320 min Summer	98.543	0.043	0.0	0.9	0.9	0.7	O K
5760 min Summer	98.538	0.038	0.0	0.7	0.7	0.6	O K
7200 min Summer	98.534	0.034	0.0	0.6	0.6	0.6	O K
8640 min Summer	98.531	0.031	0.0	0.5	0.5	0.5	O K
10080 min Summer	98.529	0.029	0.0	0.5	0.5	0.5	O K
15 min Winter	99.409	0.909	0.0	5.0	5.0	15.1	O K
30 min Winter	99.542	1.042	0.0	5.0	5.0	17.3	O K
60 min Winter	99.524	1.024	0.0	5.0	5.0	17.0	O K
120 min Winter	99.341	0.841	0.0	5.0	5.0	14.0	O K
180 min Winter	99.086	0.586	0.0	5.0	5.0	9.7	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m ³)	Discharge Volume (m ³)	Time-Peak (mins)
15 min Summer	148.070	0.0	16.6	17
30 min Summer	95.640	0.0	21.5	29
60 min Summer	58.745	0.0	26.4	46
120 min Summer	34.854	0.0	31.4	80
180 min Summer	25.354	0.0	34.2	112
240 min Summer	20.120	0.0	36.2	142
360 min Summer	14.497	0.0	39.1	198
480 min Summer	11.487	0.0	41.3	254
600 min Summer	9.583	0.0	43.1	310
720 min Summer	8.261	0.0	44.6	368
960 min Summer	6.531	0.0	47.0	490
1440 min Summer	4.684	0.0	50.6	734
2160 min Summer	3.354	0.0	54.3	1100
2880 min Summer	2.645	0.0	57.1	1444
4320 min Summer	1.890	0.0	61.2	2148
5760 min Summer	1.488	0.0	64.3	2896
7200 min Summer	1.235	0.0	66.7	3656
8640 min Summer	1.061	0.0	68.7	4272
10080 min Summer	0.932	0.0	70.5	5096
15 min Winter	148.070	0.0	18.6	17
30 min Winter	95.640	0.0	24.1	30
60 min Winter	58.745	0.0	29.6	48
120 min Winter	34.854	0.0	35.1	86
180 min Winter	25.354	0.0	38.3	120

48 West End

MBP-7764

Westbury

62 Avenue Road

Wiltshire BA13 3JG

Attenuation Storage

Date July 2019

Designed by Peter White

File Attenuation+Hydrobrake.SRCX

Checked by




Micro Drainage

Source Control 2016.1

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max E Outflow (l/s)	Max Volume (m ³)	Status
240 min Winter	98.889	0.389	0.0	5.0	5.0	6.5	O K
360 min Winter	98.683	0.183	0.0	4.6	4.6	3.0	O K
480 min Winter	98.618	0.118	0.0	4.0	4.0	2.0	O K
600 min Winter	98.598	0.098	0.0	3.4	3.4	1.6	O K
720 min Winter	98.587	0.087	0.0	2.9	2.9	1.4	O K
960 min Winter	98.573	0.073	0.0	2.3	2.3	1.2	O K
1440 min Winter	98.560	0.060	0.0	1.7	1.7	1.0	O K
2160 min Winter	98.549	0.049	0.0	1.2	1.2	0.8	O K
2880 min Winter	98.543	0.043	0.0	0.9	0.9	0.7	O K
4320 min Winter	98.536	0.036	0.0	0.7	0.7	0.6	O K
5760 min Winter	98.532	0.032	0.0	0.5	0.5	0.5	O K
7200 min Winter	98.529	0.029	0.0	0.4	0.4	0.5	O K
8640 min Winter	98.526	0.026	0.0	0.4	0.4	0.4	O K
10080 min Winter	98.525	0.025	0.0	0.3	0.3	0.4	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m ³)	Discharge Volume (m ³)	Time-Peak (mins)
240 min Winter	20.120	0.0	40.6	148
360 min Winter	14.497	0.0	43.8	200
480 min Winter	11.487	0.0	46.3	250
600 min Winter	9.583	0.0	48.3	308
720 min Winter	8.261	0.0	50.0	368
960 min Winter	6.531	0.0	52.7	490
1440 min Winter	4.684	0.0	56.6	728
2160 min Winter	3.354	0.0	60.9	1096
2880 min Winter	2.645	0.0	64.0	1472
4320 min Winter	1.890	0.0	68.6	2172
5760 min Winter	1.488	0.0	72.0	2888
7200 min Winter	1.235	0.0	74.7	3576
8640 min Winter	1.061	0.0	77.0	4408
10080 min Winter	0.932	0.0	78.9	5088

tIDC Ltd		Page 3
48 West End Westbury Wiltshire BA13 3JG	MBP-7764 62 Avenue Road Attenuation Storage	
Date July 2019 File Attenuation+Hydrobrake.SRCX	Designed by Peter White Checked by	
Micro Drainage	Source Control 2016.1	


Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.700	Shortest Storm (mins)	15
Ratio R	0.438	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.060

Time (mins)		Area
From:	To:	(ha)
0	4	0.060

tIDC Ltd		Page 4
48 West End Westbury Wiltshire BA13 3JG	MBP-7764 62 Avenue Road Attenuation Storage	
Date July 2019 File Attenuation+Hydrobrake.SRCX	Designed by Peter White Checked by	
Micro Drainage	Source Control 2016.1	

Model Details

Storage is Online Cover Level (m) 100.450

Cellular Storage Structure

Invert Level (m) 98.500 Safety Factor 2.0
 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
 Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	17.5	0.0	1.200	17.5	0.0	1.201	1.2	0.0

Hydro-Brake Optimum® Outflow Control

Unit Reference MD-SHE-0103-5000-1200-5000
 Design Head (m) 1.200
 Design Flow (l/s) 5.0
 Flush-Flo™ Calculated
 Objective Minimise upstream storage
 Application Surface
 Sump Available Yes
 Diameter (mm) 103
 Invert Level (m) 98.500
 Minimum Outlet Pipe Diameter (mm) 150
 Suggested Manhole Diameter (mm) 1200

Control Points	Head (m)	Flow (l/s)	Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.200	5.0	Kick-Flo®	0.745	4.0
Flush-Flo™	0.354	5.0	Mean Flow over Head Range	-	4.4

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake Optimum® as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	3.4	0.800	4.1	2.000	6.3	4.000	8.8	7.000	11.5
0.200	4.7	1.000	4.6	2.200	6.6	4.500	9.3	7.500	11.8
0.300	5.0	1.200	5.0	2.400	6.9	5.000	9.8	8.000	12.2
0.400	5.0	1.400	5.4	2.600	7.2	5.500	10.2	8.500	12.6
0.500	4.9	1.600	5.7	3.000	7.7	6.000	10.7	9.000	12.9
0.600	4.7	1.800	6.0	3.500	8.3	6.500	11.1	9.500	13.3

48 West End
Westbury
Wiltshire BA13 3JG

MBP-7764
62 Avenue Road
Attenuation Storage



Date July 2019
File Attenuation+Hydrobrake.SRCX

Designed by Peter White
Checked by

Micro Drainage

Source Control 2016.1

Event: 30 min Winter

