



Steve Hay
Meridian Cooling Lts

THE ROCKET, EUSTON

Tuesday, 5 February 2019


Prepared For Fairlands Contractors

9 Issues Identified



BAR AREA

No AC installed no ventilation to rear area
Arrow shows proposed area for New AC



LEFT BAR AREA

No AC installed and ventilation to front of building only
Arrow shows proposed location for new AC



VENTILATION GRILLS AT FRONT OF BUILDING ONLY

Arrow shows proposed area of New AC



BAR AREA SHOWING ONLY 2 VENTS FOR AREA

Arrow shows location of proposed AC



**HEAT EXCHANGE COIL ON THE ROOF PLANT AREA,
CURRENTLY OPERATIONAL**

This is the only form of heat other than radiators



ROOF PLANT WITH OLD VENTILATION SYSTEM

Arrow for proposed AC plant location.



TOILET EXTRACT ON ROOF PLANT AREA



REDUNDANT FRESH AIR SUPPLY FOR TOILET



LOTS OF REDUNDANT VENTILATION ON ROOF AREA