



**Armstrong House  
3 Bassett Avenue  
Southampton  
SO16 7DP**

**T: 02381 555 000  
E: [info@24acoustics.co.uk](mailto:info@24acoustics.co.uk)**

**18-20 ELSWORTHY ROAD  
LONDON**

**PLANT NOISE ASSESSMENT**

Technical Report: R8200-2 Rev 0

Date: 24th October 2019

For: Sherlock London Ltd  
64-66 Old Street  
London  
EC1V 9AN

## 24 Acoustics Document Control Sheet

**Project Title:** 18-20 Elsworthy Road, London – Plant Noise Assessment

**Report Ref:** R8200-2 Rev 0

**Date:** 24th October 2019

	Name	Position	Signature	Date
<b>Prepared by</b>	Jon Munns MEng (Hons) AMIOA	Consultant	<i>JM</i>	24/10/19
<b>Reviewed by</b>	Chris McConnell BSc MSc MIOA	Senior Consultant	<i>CM</i>	24/10/19
<b>Approved by</b>	Stephen Gosling BEng MIOA	Principal Consultant	<i>S. Gosling</i>	24/10/19
For and on behalf of 24 Acoustics Ltd				

## Document Status and Approval Schedule

Revision	Description	Prepared By	Reviewed by	Approved By
0	Approved for issue	Jon Munns	Chris McConnell	Stephen Gosling

## DISCLAIMER

This report was completed by 24 Acoustics Ltd on the basis of a defined programme of work and terms and conditions agreed with the Client. The report has been prepared with all reasonable skill, care and diligence within the terms of the Contract with the Client and taking into account the project objectives, the agreed scope of works, prevailing site conditions and the degree of manpower and resources allocated to the project.

24 Acoustics Ltd accepts no responsibility whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works.

This report is issued in confidence to the Client and 24 Acoustics Ltd has no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies upon the report at their own risk.

Unless specifically assigned or transferred within the terms of the agreement, 24 Acoustics Ltd retains all copyright and other intellectual property rights, on and over the report and its contents.

© 24 Acoustics Ltd 2019

<b>CONTENTS</b>	<b>PAGE</b>
1.0 Introduction	4
2.0 Site Description	4
3.0 Relevant Criteria	5
4.0 Noise Measurements	6
5.0 Noise Impact Assessment	7
6.0 Conclusions	9
References	10
Figures	11
Appendix A – Acoustic Terminology	13
Appendix B – Ambient Noise Survey Results	14

## **1.0 INTRODUCTION**

- 1.1 24 Acoustics Ltd has been instructed by Sherlock London to undertake a plant noise assessment to address a planning condition for the development at 18-20 Elsworthy Road, London.
- 1.2 This report presents the results of the assessments, following site visits and a background noise survey undertaken between 30th September and 1st October 2019.
- 1.3 All sound pressure levels quoted in this report are in dB relative to 20  $\mu$ Pa. A glossary of the acoustic terminology used in this report is provided in Appendix A.

## **2.0 SITE DESCRIPTION**

- 2.1 Planning permission was granted on 30th March 2015 for demolition of existing buildings and construction of five residential units, comprising: one seven-bed dwelling house, one four-bed maisonette, one three-bed flat and two one-bed flats. The development includes roof level plant, a mechanical ventilation and heat recovery (MVHR) unit in an external lightwell and toilet extract fans on each façade.
- 2.2 The nearest noise-sensitive property to the proposed plant is 16 Elsworthy Road, located to the north-east of the site.
- 2.3 It is understood that the proposed plant will operate on demand at any time of day or night. Therefore, this assessment will consider the specific noise level from the plant against daytime and night-time background noise levels.
- 2.4 An aerial view of the site and the noise survey measurement locations are shown in Figure 1, and the proposed locations of the plant are shown in Figure 2.

### 3.0 RELEVANT CRITERIA

#### BS 4142:2014+A1:2019 Methods for Rating Industrial and Commercial Sound

- 3.1 BS 4142:2014+A1:2019 [Reference 1] provides a method for rating the effects of industrial and commercial sound on residential receptors.
- 3.2 The standard advocates a comparison between the representative measured  $L_{A90}$  background noise level and  $L_{Aeq}$  noise level from the source being considered. For rating purposes if the noise source is tonal, intermittent, or otherwise distinctive in character, a rating correction should be applied.
- 3.3 The standard states that a difference between the rating level and the background level of around +10 dBA is an indication of a significant adverse impact, depending on the context and a difference of around +5 dBA is likely to be an indication of an adverse impact, also depending on the context. Where the rating level does not exceed the background noise level, this is an indication of the specific sound source having a low impact (depending upon the context).
- 3.4 BS 4142 requires the noise impact to be assessed depending on the context. In relation to situations where background noise levels are low, the standard states "Where background sound levels and rating levels are low, absolute levels might be as, or more, relevant than the margin by which the rating level exceeds the background. This is especially true at night".

#### Planning Permission 2014/5413/P

- 3.5 Condition 4 of the planning permission relates to noise levels from plant and is reproduced below:

*Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement ( $LA_{90}$ ), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the  $LA_{90}$ , expressed in dB(A).*

## 4.0 NOISE MEASUREMENTS

### Background Noise Survey

- 4.1 A background noise survey was undertaken between 30th September and 1st October 2019 to assess the existing background noise levels, using the following equipment:
- Rion precision sound level meter Type NL-52;
  - Norsonic acoustic calibrator Type 1251.
- 4.2 Measurements were undertaken in samples of 5 minutes in terms of the overall free-field A-weighted  $L_{eq}$ ,  $L_{90}$  and  $L_{max,f}$  noise levels. Measurements were made in accordance with BS 7445:1991 "Description and measurement of environmental noise Part 2 - Acquisition of data pertinent to land use" [Reference 6]. The measurement location is shown on Figure 1.
- 4.3 The instrumentation calibration was checked before and after the surveys in accordance with the manufacturer's instructions. No significant drift in calibration was recorded. Calibration of 24 Acoustics' equipment is traceable to National Standards.
- 4.4 The instrumentation was fitted with environmental weather shields during the surveys. Periods affected by rainfall and works on site have been excluded from the analysis.
- 4.5 As the plant will operate on demand over 24 hours, it is considered appropriate to base the assessment on the night-time background noise levels. The results of the background noise survey are shown graphically in Appendix B and are summarised in Table 1 below.

<b>Typical Night-Time Background (23:00 – 07:00 hours)</b> <b>Sound Pressure Level (dB <math>L_{A90,15min}</math>)</b>	
45	

**Table 1:** Summary of measured night-time background noise level.

- 4.6 Please note that 24 Acoustics defines the typical background noise level to be the average level minus one standard deviation.
- 4.7 Based on the measured background noise levels, in accordance with the criteria from planning condition 4, noise levels from plant should not exceed 40 dB  $L_{Aeq,15min}$  at the nearest noise sensitive façades.

## 5.0 NOISE IMPACT ASSESSMENT

### Plant Noise Data

- 5.1 It is proposed to install new plant as outlined below. Locations of the proposed units are shown in Figure 2.
- 1 × Nuaire MRXBOXAB-ECO4 MVHR unit in the lower ground floor lightwell on the western boundary of the site;
  - 3 × Daikin ERLQ016CV3 condenser units on the roof;
  - 15 × VES Turbo 100 toilet extract fans;
  - 2 × Nuaire NA-E-150T toilet extract fan;
  - 2 × Nuaire ES-OPUSDC75-M toilet extract fans.
- 5.2 Of the toilet extract fans, only two contribute significantly to noise levels at sensitive properties: one VES Turbo 100 and one Nuaire ES-OPUSDC75-M exhaust from the eastern façade of the building, near 16 Elsworthy Road. The remainder of the extract fans exhaust to roof level or other façades and are not considered to contribute significantly to noise levels at the nearest sensitive windows.
- 5.3 The nearest sensitive receptor to the proposed plant is 16 Elsworthy Road, immediately adjacent to the east of the site. The nearest window at the front of the property is approximately 5 metres from the lightwell containing the Nuaire MVHR unit, and 15 metres from the nearest condenser. The nearest window at the rear of the property is 12 metres from the nearest condenser, and 15 metres from the lightwell but completely screened by the building. The extract fan terminations on the façade are approximately 3 metres from the front of 16 Elsworthy Road but screened by the edge of the building.
- 5.4 The manufacturer's sound power level data for the Nuaire MVHR unit and Nuaire ES-OPUSDC75-M extract fan has been provided and is shown in Table 2 below. 24 Acoustics understands that the design duty of the Nuaire MVHR unit is 50%.

Sound Power Level (dB) at Octave Band Centre Frequency (Hz)									dBA
Unit	63	125	250	500	1k	2k	4k	8k	
Nuaire MRXBOXAB-ECO4 open inlet (50 % duty)	44	48	45	43	37	33	19	<16	44
Nuaire MRXBOXAB-ECO4 open outlet (50 % duty)	51	58	58	55	49	47	38	31	56
Nuaire ES-OPUSDC75-M induct outlet	71	69	58	54	52	48	42	33	58

**Table 2:** Manufacturer's sound power level data.

- 5.5 The manufacturers' sound pressure level data measured at specific distances for the Daikin ERLQ016CV3 condenser units and VES Turbo 100 toilet extract fan has been provided and is shown in Table 3 below.

Sound Pressure Level at specified distance (dB) at Octave Band Centre Frequency (Hz)									dBA
Unit	63	125	250	500	1k	2k	4k	8k	
Daikin ERLQ016CV3 @ 1 m	54	56	55	56	48	47	40	32	56
VES Turbo 100 outlet @ 3 m	-	-	-	-	-	-	-	-	36

**Table 3:** Manufacturers' sound pressure level data, at specified distance.

#### Noise Impact Assessment

- 5.6 Assessments of noise impact from the proposed plant have been undertaken for the front and rear of the nearest sensitive property, 16 Elsworthy Road.
- 5.7 The proposed plant is not considered to contain tonal or other distinctive characteristics; therefore, under the planning condition, the total noise at each receptor will need to achieve 5 dBA below the background noise level as per Condition 4.
- 5.8 The calculations have included losses due to distance, screening from the roof edge and building, and ductwork losses, as well as a correction for some of the plant being located in a lightwell. The assessments of noise from the proposed plant against the typical night-time background noise level for the front and rear of 16 Elsworthy Road are shown in Table 4 below.

	Front of 16 Elsworthy Road	Rear of 16 Elsworthy Road
<b>Representative background noise level</b>	45 dB LA90,15min	45 dB LA90,15min
<b>Plant noise level</b>	32 dB LAeq	29 dB LAeq
<b>Level difference</b>	-13 dBA	-16 dBA

**Table 4:** Plant noise assessments

- 5.9 Table 4 shows that noise levels from the proposed plant will not exceed 5 dBA below the typical night-time background noise level and will therefore comply with the planning condition.




## **6.0 CONCLUSIONS**


- 6.1 24 Acoustics Ltd has been instructed by Sherlock London to undertake a plant noise assessment to address a planning condition for the development at 18-20 Elsworthy Road, London.
- 6.2 An environmental noise survey has been undertaken to determine the existing background noise levels representative of nearby residential properties.
- 6.3 Calculations have been undertaken, based on manufacturer's noise data, to determine the plant noise levels at the nearest noise sensitive windows.
- 6.4 The assessment shows that noise from the proposed plant will comply with the planning condition and will therefore be acceptable.


## REFERENCES

1. British Standards Institution. British Standard 4142:2014+A1:2019 Methods for rating industrial and commercial sound, 2019.
2. British Standards Institution. British Standard 7445: 1991 Description and measurement of environmental noise Part 2 - Acquisition of data pertinent to land use.







<b>Project:</b> 18-20 Elsworthy Road, London	<b>Title:</b> Plant locations.		 24Acoustics
<b>DWG No:</b> Figure 2	<b>Scale:</b> N.T.S.	<b>Rev:</b> 0	
<b>Date:</b> October 2019	<b>Drawn By:</b> JM	<b>Job No:</b> 8200	

## APPENDIX A – ACOUSTIC TERMINOLOGY

Noise is defined as unwanted sound. The range of audible sound is from 0 to 140 dB. The frequency response of the ear is usually taken to be around 18 Hz (number of oscillations per second) to 18000 Hz. The ear does not respond equally to different frequencies at the same level. It is more sensitive in the mid-frequency range than the lower and higher frequencies and because of this, the low and high frequency components of a sound are reduced in importance by applying a weighting (filtering) circuit to the noise measuring instrument. The weighting which is most widely used and which correlates best with subjective response to noise is the dBA weighting. This is an internationally accepted standard for noise measurements.

For variable sources, such as traffic, a difference of 3 dB is just distinguishable. In addition, a doubling of traffic flow will increase the overall noise by 3 dB. The 'loudness' of a noise is a purely subjective parameter, but it is generally accepted that an increase/ decrease of 10 dB corresponds to a doubling/ halving in perceived loudness.

External noise levels are rarely steady, but rise and fall according to activities within an area. In attempt to produce a figure that relates this variable noise level to subjective response, a number of noise indices have been developed. These include:

i) The  $L_{Amax}$  noise level

This is the maximum noise level recorded over the measurement period.

ii) The  $L_{Aeq}$  noise level

This is "equivalent continuous A-weighted sound pressure level, in decibels" and is defined in British Standard BS 7445 as the "value of the A-weighted sound pressure level of a continuous, steady sound that, within a specified time interval, T, has the same mean square sound pressure as a sound under consideration whose level varies with time".

It is a unit commonly used to describe construction noise and noise from industrial premises and is the most suitable unit for the description of other forms of environmental noise. In more straightforward terms, it is a measure of energy within the varying noise.

iii) The  $L_{A10}$  noise level

This is the noise level that is exceeded for 10% of the measurement period and gives an indication of the noisier levels. It is a unit that has been used over many years for the measurement and assessment of road traffic noise.

iv) The  $L_{A90}$  noise level

This is the noise level that is exceeded for 90% of the measurement period and gives an indication of the noise level during the quieter periods. It is often referred to as the background noise level and is used in the assessment of disturbance from industrial noise.

APPENDIX B – AMBIENT NOISE SURVEY RESULTS

