



**ENVIRONMENTAL HEALTH
SUPPORTING COMMUNITIES**

To:	<i>Mark Chan, Planning Officer, Development Management, 5 Pancras Square</i>
From:	<i>Edward Davis (Pollution Planning Consultant)</i>
Date:	24 November 2019
Re:	<i>11 Monmouth Street London WC2H 9EQ</i>
Proposal:	<i>Alterations to shopfront and installation of 2x HVAC condenser units on rear elevation.</i>
Reference:	<i>2019/4442/P</i>
Key Points:	The proposals are <u>unacceptable</u> in environmental health terms

I have taken a look at the submitted details which has proposed Alterations to shopfront and installation of 2x HVAC condenser units on rear elevation. The applicant has submitted a HVAC design to support the application.

The design itself is satisfactory but the applicant has failed to submit an acoustic assessment in support of the design of the system.

Therefore I have to suggest that the application is rejected until sufficient information is submitted in support of the design.

If you have any queries, please do not hesitate to contact me.

Regards

Edward Davis
Pollution Planning Consultant