

**From:** Ovunc Ozbaris

**Sent:** 01 December 2019 19:59

**To:** Young, Tony

**Cc:** Nabil Jerashy; Aylin Alkan; kerem alkan

**Subject:** Re: Householder application - 2019/4528/P - The Coach House, 2 Rosslyn Hill

Dear Tony

Please find attached revised detail drawing NoD01R and new detail drawing NoD02 (scale 1/25) accordingly.

a) please see doors closed plan on both drawings NoD01R & D02.

c) please see proposed section drawing (NoD02) scale 1/25 attached as you required. The aluminium cladding band over the opening on previous detail drawing was for covering the proposed beam over the opening. However the structural engineer recently submitted their detail drawing which marked the proposed beam to be installed to the inner face of the existing wall instead of outer face so I have revised elevation drawings as 'soldier brick over the doors to match existing' (please see attached drawings NoD01R and existing photo).

d) SHS: Square Hollow Section (steel square post). This is proposed by the structural engineer for the corner as supporting column where the existing wall will be removed.

Kind regards

O.Ozbaris