

| | | | |
|--|--|-------------------------------------|-------------|
| LDC (Proposed) Report | | Application number | 2019/5240/P |
| Officer | | Expiry date | |
| Nathaniel Young | | 09/12/2019 | |
| Application Address | | Authorised Officer Signature | |
| 54 Lady Somerset Road London NW5 1TU | | | |
| Conservation Area | | Article 4 | |
| | | Basements | |
| Proposal | | | |
| Erection of a hip to gable roof extension and rear roof extension; and installation of 1 front rooflight | | | |
| Recommendation: | | Grant Certificate of Lawfulness | |

The application site contains a three-storey end-of-terrace dwellinghouse on the northern side of Lady Somerset Road. It is not in a conservation area. The proposal is considered to be permitted development as it meets the criteria listed below.

| | | |
|--|--|--------|
| Class B | | |
| The enlargement of a dwellinghouse consisting of an addition or alteration to its roof | | |
| If yes to any of the questions below the proposal is not permitted development | | Yes/no |
| B.1(a) | As a result of the works, would any part of the dwellinghouse exceed the height of the highest part of the existing roof? | No |
| B.1(b) | As a result of the works, would any part of the dwellinghouse extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway? | No |
| B.1(c) | As a result of the works, would the cubic content of the resulting roof space exceed the cubic content of the original roof space by more than— (i) 40 cubic metres in the case of a terrace house, or (ii) 50 cubic metres in any other case? | No |
| B.1(d) | would it consist of or include— (i) the construction or provision of a veranda, balcony or raised platform, or (ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe? | No |
| B.1(e) | Is the dwellinghouse on article 1(5) land? | No |
| B.2(a) | Would the materials used in any exterior work not be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse? | No |

| | | |
|---|--|----|
| B.2(b) | Other than in the case of a hip-to-gable enlargement, would the edge of the enlargement closest to the eaves of the original roof be less than 20 centimetres from the eaves of the original roof, so far as practicable? | No |
| B.2(c) | Would any windows inserted on a wall or roof slope forming a side elevation not be obscured-glazed and non-opening unless the opening part is higher than 1.7 metres above the floor of the room in which the window is installed? | No |
| Class C Any other alteration to the roof of a dwellinghouse | | |
| C.1(a) | As a result of the works, would the alteration protrude more than 150 millimetres beyond the plane of the slope of the original roof when measured from the perpendicular with the external surface of the original roof? | No |
| C.1(b) | As a result of the works, would it result in the highest part of the alteration being higher than the highest part of the original roof? | No |
| C.1(c) | Would it consist of or include— (i) the installation, alteration or replacement of a chimney, flue or soil and vent pipe; or (ii) the installation, alteration or replacement of solar photovoltaics or solar thermal equipment? | No |
| Condition. If no to the question below then the proposal is not permitted development | | |
| C.2 | Would any upper-floor window located on a roof slope forming a side elevation of the dwellinghouse not be— (a) obscure-glazed, and (b) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed? | No |