

T 020 7434 2277

E [info@giannibotsford.com](mailto:info@giannibotsford.com)  
[www.giannibotsford.com](http://www.giannibotsford.com)

Gianni Botsford Architects Ltd  
Fourth Floor  
20-24 Kirby Street  
London EC1N 8TS

Development Management  
Camden Town Hall  
Extension  
Argyle Street  
London  
WC1H 8EQ

05.12.2019

Re:  
13A Pond Street,  
London  
NW3 2PN

Dear Sir or Madam,

**RE: Application for non- material amendment (Air Source Heat Pump/ PV Panels) to approval 2017/6907/P**

I am writing to submit an application for a non-material amendment to the above planning approval. This letter accompanies the following documents:

1. Associated amended drawings showing the location of a new proposed Air Source Heat Pump and enclosure to the north-west of the site; the removal of the PV panels on the main roof of the building.
2. Energy Strategy Update letter from Integration (Services Engineer).
3. Noise Assessment and Mitigation Report.

In the course of the detail design development for the above project and following several detailed studies in relation to the environmental strategy, it is proposed to switch from a gas boiler to air source heat pump (ASHP).

The new ASHP is proposed to be located in the north-eastern corner of the garden at 13A Pond Street, where it is non-visible from neighbouring properties.

Moreover it is proposed to omit the PV panels on the main roof, which would be overshadowed mainly by the surrounding trees and therefore perform very poorly.

In Summary, the revised SAP calculations as outlined in the Energy Strategy Update letter prove that the switch to an ASHP (despite the omission of PV Panels) still achieve and exceed the sustainability targets as originally set out in the Sustainability and Energy Statement.

Please feel free to contact us should you have any queries

Yours sincerely,



Stephanie Aue  
For and on behalf of Gianni Botsford Architects Ltd