



**Q37 Specification for
Scenario Architecture
Sky Garden Sedum Blanket System
For: Bernard Farrant**

24/10/2019

This specification is based on current information available at the time of writing, if any aspects are revised prior to construction, or you require any additional details. Please contact our Technical Services Dept who would be pleased to amend or update the information provided.



Q37 GREEN ROOFS

To be read with Preliminaries / General Conditions

GENERAL

130 EXTENSIVE GREEN ROOF

Roof type: J42 (Single Ply)
Substrate: As J42
Slope: As J42
Waterproofing: As J42
Thermal Insulation: As J42
Protection: Protection fleece as clause 330
Moisture Control: Drainage layer as clause 350
Growing medium: Soil-less substrate as clause 390
Vegetation: Sedum blanket as clause 400

Accessories:

Filter fleece as clause 360
Surface habitat creation as clause 392
Wall mounted habitats as clause 393
Irrigation as clause 401
Aftercare as clause 402
Edge retaining profile as clause 420
Separation edge as clause 420/b
Border as clause 460
Intermediate restraints as clause 820A

PERFORMANCE

210 GENERAL DESIGN

Green roof and associated features: Complete the detailed design.
Proposals: Submit drawings, technical information, calculations and manufacturers' literature.
Performance criteria: As per design requirements.

250 CHARACTERISTIC ROOF LOADS

Roof structure: The structural engineers must satisfy themselves that the roof structure and deck are suitable to receive the dead load of the proposed green roof system and landscape both during construction and on completion of the works.

Living Roof: 58kg/m2 (Saturated)

Allowance for additional loads during construction: To be advised
Requirement: Restrict site activities to ensure that design loads are not exceeded, or submit proposals for temporary supports.



PRODUCTS

- 320 **ROOT BARRIER to Extensive Roof**
Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk
Product reference: N/A
Material: N/A
Thickness: N/A
- 330 **PROTECTION LAYER To Extensive Roof**
Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk
Product reference: SGPL0102
Material: Tensile geo-synthetic protection layer
Thickness: 3.5 mm
- 350 **DRAINAGE LAYER To Extensive Roof**
Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk
Product reference: SGDRRD20
Material: HDPE rigid drainage and retention board with high compressive strength.
Depth: 20 mm
Infill: Shingle Over
- 360 **FILTER MEMBRANE To Extensive Roof**
Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk
Product reference: SGFF01
Material: 150gsm non-woven polypropylene fibre filter membrane bonded to drainage layer
Thickness: 1.5 mm
- 390 **EXTENSIVE LIGHTWEIGHT GROWING MEDIUM**
Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk
Product reference: SGLSB50
Material: Screened blend of recycled crushed brick and lightweight mineral materials with 20% organic matter (PAS100 recycled green waste)
Depth: 40 mm
Ameliorant/ conditioner: N/A
Coverage: Total.
Declaration of analysis: Submit.
Parameters: Consistent installation of product to filter layers provided.



- 391 ROOF FINISH CONTOUR To Extensive Roof
Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk
Product Reference:N/A
Material:N/A
- 392 SURFACE HABITAT CREATION To Extensive Roof
Manufacturer: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Product Reference:surface habitats to increase biodiversity.
Material:N/A
- 393 WALL MOUNTED HABITAT To Extensive Roof Boundaries
Manufacturer: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Product Reference: N/A
Material: N/A
- 400 VEGETATION To Extensive Roof
Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk
Product reference: **SB1001**
Density: pre-grown blanket (12 month minimum established) at point of installation.
Vegetation coverage at installation minimum (90% coverage) installed.
Planting mix: 8-12 species from the following: Sedum Album Coral Carpet, Sedum Album Minor, Sedum Lydium, Sedum Sexangulae, Sedum Acre, Sedum Hispanicum Minus, Sedum Hybriden, Sedum Floriferum Gold, Sedum Spurium, Sedum Kamschaticum, Sedum Angelina & Sedum Reflexum. Species according to seasonal availability.
Additional: A greater range of species and additions of wildflower, cornflower, herb and alpine mixes can be added as a regional pre-grown blanket or as a post installation over seed and should be discussed at planning stage.
- 401 IRRIGATION
The green roof will need thorough saturation following installation. Immature systems will require a supplementary irrigation system to be available for the first 12 months of the establishment period. Blanket systems may need supplementary watering during periods of extended drought, especially for the first 2 years' post installation.
It is strongly recommended that a connection at roof height is left for systems to connect with providing a roof pressure of 2.5-3bar and a flow rate of 60L/min.

A two-visit inspection and remedial package for year 1 maintenance (unless longer agreed) to manage the roof establishment period. Aftercare program should not cover watering but should cater for commissioning and de-commissioning of the irrigation system.

System/drainage outlet checks and removal of invasive/unwanted plants to be included.

Remedial aftercare to cover failure of the green roof to establish under certain criteria but not damage caused by other services, e.g. birds, theft, vandalism or extreme weather damage.

420

EDGE RETAINING PROFILE

Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk

Product Reference: SGRE100100

Material: 2mm tensile aluminium upstand with corner fixings and perforations

Height: **100mm**

Foot: **100mm**

420/b

SEPARATION PROFILE

Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk

Product Reference: SGRE100100

Material: 2mm tensile aluminium upstand with corner fixings and perforations

Height: **100mm**

Foot: **100mm**

460

BORDERS

Type: Riverstone Pebbles

Supplier: Sky Garden Ltd, 7&8 Keil Close, Broadway, Worcestershire, WR12 7DP
Contact: Sarah Byrne T: 07725258580 E: sarah.byrne@sky-garden.co.uk

Size: 20-40mm rounded, washed

Colour: Multi-colour, mixed grade natural finish (minimal sharp edges but not guaranteed as stone damage during bagging and transport can occur)

Laying: 0 mm borders around perimeters, penetrations and outlets (25kg sack units) with reduced width by agreement, according to location/adjacent finishes.

EXECUTION



- 710 **INSTALLATION GENERALLY**
Preparation: Clear all surfaces of debris.
Timing: After certification of waterproof membrane integrity.
Surface condition: Visually inspect waterproof membrane, report any damage.
Faults in waterproof membrane: Report.
Contamination: Do not use materials detrimental to healthy plant growth.
Storage: Do not overload.
Point loads: Avoid.
Outlets: Do not block.
Outlet grilles: Installed (by roofing contractor)
- 720 **ADVERSE WEATHER**
Unfinished work: Secure from damage and wind uplift.
Conditions: Do not install or work with frozen materials.
- 740 **ROOT BARRIER INSTALLATION**
Joints: Minimize
Overlaps (minimum): 100mm
- 750 **PROTECTION LAYER INSTALLATION**
Joints: Minimize
Overlaps (minimum): 100mm
Upstands: Extend to top of growing medium.
- 770 **DRAINAGE LAYER INSTALLATION**
Extent: Continuous beneath living roof area
Fitting: Loose laid
Up stands: Fit closely around penetrations and outlets.
- 780 **FILTER MEMBRANE INSTALLATION**
Joints: Minimize
Overlaps (minimum): 100mm
Fitting: Loose Laid
Upstands: Extend to top of growing medium.
- 790 **GROWING MEDIUM INSTALLATION**
Handling: Minimize.
Conditions: Handle in the driest condition possible. Do not handle or install wet or frozen.
Layers: N/A
Depth (maximum): as per Q37 clause 390
Sequence: Gently firm each layer before spreading the next

800 **VEGETATION INSTALLATION**



Vegetation: Foliage upright. Avoid tearing blanket. Lift from beneath root zone/carrier, not foliage. Minimise foot traffic or laying of materials on to blanket during or after installation.

Conditions: Blankets should be moist but not saturated nor dry. Do not handle or install when frozen.

Surface preparation: Ensure substrate surface is flat and even before laying blanket

Layers: Lay blanket root zone on to substrate ensuring direct contact with substrate across entire surface. Ensure no air pockets between substrate and root zone.

Sequence: Remove from pallets on same day of delivery. Open rolls with foliage upwards and lay direct onto substrate. Gently firm blanket onto substrate surface. Water in on day of installation.

820 EDGE RETAINING PROFILE INSTALLATION

Cutting: Neat, accurate and without spalling.

Junctions: Vertical, secured using proprietary connectors.

Position: True to line and level. Smooth continuous lines.

Fixing: Spot bonded with manufacturers approval or system ballasted

Retention detail used where there are system retention requirements and should be sport bonded in accordance with manufacturers approval or system ballasted.

Separation detail if for physical divide between system and slab or stone detailing and is system ballasted.

840A INTERMEDIATE RESTRAINTS INSTALLATION

Intermediate restraints should be fitted across the roof on pitches exceeding 10°. Refer to specification and design detail or waterproof system manufacturer detail for type and fixing method.

As a guide, retention battens on pitches from 10°-20° should be installed at 2000mm increments up the roof slope with a mechanical fixing at eaves. From 21°-45° the spacing should be reduced to 1000mm. The height of the restraints should not exceed the combined height of the drainage and substrate layers

840 LAYING BORDER

Condition of substrate: Clean.

Gravel guards: Fit to outlets.

Laying: 0 mm borders around perimeters and outlets - spread evenly, do not pile to excessive heights

Depth (minimum): 0 mm

Previously laid materials: Protect during the spreading of Riverstone Pebbles

COMPLETION

910 INSPECTION



Give notice (minimum): 3 days.

920

COMPLETION

General: Leave the works in a clean, tidy condition.

Surfaces: Clean immediately before handover.

Outlets: Clean and clear of obstructions.

Completed green roof: Protect from adjacent or high level working.

930

DOCUMENTATION

Timing: Submit at handover.

Contents: Growing medium declaration of analysis.

Manufacturers' guarantees and warranties

Procedures for maintenance of the green roof

Record drawings showing the location of planting and associated features

Aftercare agreement

O&M Manual

Irrigation guidelines

Number of copies: As required.

940

MAINTENANCE

This should consist of a minimum of two visits per year by the appropriate labour force, which will be dictated by the roof area. Irrigation is unlikely to be required once the plant layer is established.

Establishment of immature systems 18-36 months and blanket systems 12-18 months.

