

Mr Julian Bunting
ig9 Limited
31 Riverside Building
Trinity Bouy Wharf
64 Orchard Place
London
E14 0JY

Application Ref: **2013/8169/P**
Please ask for: **Hugh Miller**
Telephone: 020 7974 **2624**

12 May 2014

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) Order 2010
Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:
183 Eversholt Street
London
NW1 1BU

Proposal:
Installation of 2 x new air conditioning units to the roof of office block.

Drawing Nos: Location plan; 1314-100747-010; 1314-100747-013 Front Elevation; 1314-100747-013 Rear Elevation; 1314-100747-011 Proposed Roof Plan; Heritage Statement (1314/100747, December 2013); Design & Access Statement (Ref:1314/100747, November 2013).

The Council has considered your application and decided to grant permission subject to the following conditions:

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 The development hereby permitted shall be carried out in accordance with the following approved plans and documents:

Location plan; 1314-100747-010; 1314-100747-013 Front Elevation; 1314-100747-013 Rear Elevation; 1314-100747-011 Proposed Roof Plan; Heritage Statement (1314/100747, December 2013); Design & Access Statement (Ref:1314/100747, November 2013).

Reason:

For the avoidance of doubt and in the interest of proper planning.

- 3 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 4 Automatic time clocks shall be fitted to the equipment hereby approved, prior to commencement of the use of the units, to ensure that the plant equipment does not operate between 23:00 hrs and 07:00 hrs. The timer equipment shall be permanently maintained and retained thereafter.

Reason: To safeguard the amenities of the adjoining occupiers in accordance with the requirements of policies CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

Informatives:


- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to

Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

Your attention is drawn to the notes attached to this notice which tell you about your Rights of Appeal and other information.

Yours faithfully

A handwritten signature in black ink, appearing to read 'Rachel Stopard', with a horizontal line underneath.

Rachel Stopard
Director of Culture & Environment

It's easy to make, pay for, track and comment on planning applications on line. Just go to www.camden.gov.uk/planning.

It is important to us to find out what our customers think about the service we provide. To help us in this respect, we would be very grateful if you could take a few moments to complete our [online planning applicants' survey](#). We will use the information you give us to monitor and improve our services.