

| Source | Drawing Number | Rev |
|----------------------------|---|-----|
| Saunders Boston Architects | PS01001-SBA-XX-B1-DR-A-0023_RevC1_GA Plans_Basement | |
| Saunders Boston Architects | PS01001-SBA-XX-00-DR-A-0024_RevC1_GA Plans_Ground | |
| Saunders Boston Architects | PS01001-SBA-XX-ZZ-DR-A-0025_RevC1_GA Plans_First & Second | |
| Saunders Boston Architects | s Boston Architects PS01001-SBA-XX-ZZ-DR-A-0026_RevC1_GA Plans_Third & Roof | |
| | | |



WORKTOP CONTROLLING UNSWITCHED SOCKET OUTLET BELOW WORKTOP FOR FRIDGE

OUTLETS TO SERVE SCREENS -



AV Details Meeting Room

Small Power & Data Meeting Room




The design team have highlighted unusual and significant risks that may not be obvious to a competent contractor. They are to assist with risk reduction only and are not necessarily comprehensive. It is assumed that all works will be carried out by a competent contractor working, where appropriate, to an approved method statement.

GENERAL NOTES

- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL PROJECT SPECIFIC DESIGN CALCULATION DOCUMENTS AND SCHEDULES PRODUCED BY CARMEL MEP.
- 2. ANY DISCREPANCIES IN THE DETAILED INFORMATION SHOULD BE BROUGHT TO THE ATTENTION OF CARMEL MEP.

LEGEND **-**13A TWIN SWITCHED SOCKET OUTLET -13A SINGLE SWITCHED SOCKET OUTLET ---SWITCHED FUSED CONNECTION UNIT _ USWITCHED FUSED CONNECTION UNIT DATA OUTLET (N DENOTES No. OF GANGS) гZ SINGLE PHASE ISOLATOR



HAN DRYER WATER HEATER CLEANERS HEATING CIRCULATOR PUMP PRESSURISATION UNIT BOOSTER PUMP WATER CONDITIONER



X/Y

FLOOR BOX -X - DENOTES NUMBER OF DOUBLE SOCKETS Y = DENOTES NUMBER OF DATA POINTS

| C8 | Mods As Shown | NB | GD | 21-11-19 |
|------|------------------------------------|-------|-------|----------|
| C7 | Instructed power amendements | DC | AB | 12-11-19 |
| C6 | Supplies to electric heaters added | AB | GD | 24-10-19 |
| C5 | Construction Issue | NB | GD | 18-10-19 |
| C4 | Construction Issue | KL | GD | 27-09-19 |
| C3 | Construction Issue | NB | GD | 12-09-19 |
| C2 | Construction Issue | NB | GD | 09-09-19 |
| C1 | Construction Issue | JB | GD 1 | 9-08-19 |
| rev. | description | drawn | chkd. | date |

Carmel (UK) Ltd

University College

London

91 Gower Street

Small Power Services

First Floor

Stage 4

Revision

Signature

C8

nitials

6000 - DRG - ZZZ - 01 - DR - E - 6203

1:50@A1

Scale

Carmel (UK) Limited Midland House, Midland Place

S43 4FR

KT19 9BE

Barlborough

Chesterfield

Derbyshire

Epsom

Surrey

Client

Address

Title

Drawing Nº.

Project Nº.

1790

10m

Final Check For Issue

(uncontrolled copy unless signed)

Unit A, Blenheim House
1 Blenheim Road

Tel.: +44 (0) 1246 575 800 Fax.: +44 (0) 1246 575 801 e-mail: chesterfield@carmel-uk.com Tel.: +44 (0) 1246 575 800 Fax.: +44 (0) 1372 746 301 e-mail: epsom@carmel-uk.com Date CONSTRUCTION